

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2014/ 52 / 670

Dated: 02/06/14

FIRE SAFETY CERTIFICATE

Certified that the Guest House **Classic** located at 17A/59, WEA, Karol Bagh, New Delhi-110005 is comprised of Basement, ground floor plus four upper floors, using basement as hall/storage, ground floor as reception and offices, first floor having 07 guest rooms, second floor having 06 guest rooms, third floor having 05 guest rooms and a store on fourth floor (Total 18 guest rooms) was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2011/1143 dated 10.06.2011 owned/occupied by Sh. Jitender Chadha. The guest house building was re- inspected by the officers concerned of this department on 26.05.2014 in the presence of Sh. Vijay Sharma (Manager) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....02/06/14.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No.18454/Joint C.P./Lic.(H), Dated 30.04.2014)
2. Sh. Jitender Chadha (Owner),
Guest House Classic, 17A/59,
WEA, Karol Bagh, New Delhi-110005.
3. The Commissioner, North Delhi Municipal Corporation,
4th floor, Dr. SPM Civic Centre, Minto Road, New Delhi-110002.
(with request to measure the height and inform to this Deptt.)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Basement, Ground Floor plus Four Upper Floors.

N/15-

INSPECTION REPORT

1. Name & address of the building : G.H Classic, 17A/59, WEA, Karol Bagh, N.D.-05.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/GH/2011/1143 Date 10.06.2011
5. Fire Safety directives letter No : -
6. Date of inspection : 26.05.2014
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Vijay Sharma (Manager)
9. Year of Construction : 1994
10. Applicant's letter No. : 18454/ Joint C.P./Lic. (H) dated 30.04.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	<u>Accessible</u>	<u>09mtr</u>	<u>MR</u>
	• Gate width	<u>-</u>	<u>182cms</u>	<u>MR</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>-</u>	<u>One</u>	<u>MR, Being Old Case</u>
	• Basements	<u>-</u>	<u>-do-</u>	<u>-do-</u>
	b. Width of staircases			
	• Upper Floor	<u>-</u>	<u>125cms</u>	<u>MR, Being Old Case</u>
	• Basements	<u>-</u>	<u>117cms</u>	<u>-do-</u>
	c. Protection of exits			
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	d. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	e. Width of Corridor	<u>-</u>	<u>One</u>	<u>-</u>
	f. Door Size	<u>-</u>	<u>250cms, 131cms</u>	<u>-</u>
		<u>-</u>	<u>83cms x 204cms</u>	<u>-</u>
3.	Compartmentation			
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Sealing of electrical shafts	<u>-</u>	<u>Sealed</u>	<u>-</u>
	• Fire Rating of shaft door	<u>-</u>	<u>-</u>	<u>-</u>
	• Water Curtain	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire Dampers	<u>-</u>	<u>-</u>	<u>-</u>
4.	Smoke Management System			
	• Basements	<u>30 a/c per hour</u>	<u>Exhaust Fans are Provided</u>	<u>MR</u>
	• Upper floors		<u>Natural Ventilation</u>	<u>MR</u>

17A/59, WEA, Karol Bagh,
New Delhi - 110005.

M/17

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		-	450 LPM	MR, Old Case
		-	30 M	-do-
		Required	Provided	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	Provided	MR
		-	-	-
		-	5000 Ltr	MR, Old Case
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	-
		-	-	-
		-	Provided	MR
		Required	-do-	MR
		-do-	-do-	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		Required	Provided	MR
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

N/18 -

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.G/NFS/MS/GH/2011/1143 dated 10.06.2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.




27/5/14

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer


29/5

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer