

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax: 23412593, Tel: 011-23414333

NO.F6/ DFS/ MS/School/2014/ 52/679

Dated: 04/06/14


FIRE SAFETY CERTIFICATE

Certified that **Japanese School**, Located at Sector-A, Pocket B & C, Vasant Kunj, New Delhi-110070 comprised of Ground + 03 Upper floor, having total 20 rooms. owned/occupied by school management. The school building was inspected by the officer concerned of this department on 20/05/2014 in the presence of Mr. Sourabh Chauhan(Site Incharge) and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational (School)** with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on ~~24/06/14~~ at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

o/c


30/5/14
ADD(BUP)

Copy to: -

The Authorised Signatory
Japanese School,
Sector-A, Pocket B & C, Vasant Kunj,
New Delhi-110070

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Japanese School, Sector-A, Pocket B & C, Vasant Kunj,
New Delhi- 110070
2. Type of Occupancy : Educational (School)
3. Type of Case : New (Addition of new block)
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2013/435 dated 31/01/13
6. Date of inspection : 20/05/2014
7. Name of the Inspecting Officers : ADO D.B.Mukherjee
8. Name and designation of officers from the building side : Mr. Sourabh Chauhan (Site Incharge)
9. Year of Construction : 2013-2014
10. Applicant's letter No. : Nil dated: 07/05/2014,
(Building is comprised of Ground Plus Three Upper Floors)

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 m	Provided	MR
	• Gate width	05 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	Upper Floors	02 Nos.	Provided	N/A
	Basements	N/A	N/A	N/A
	b. Width of staircases			
	Upper Floors	1.50 m	Provided	MR
	Basement	N/A	N/A	N/A
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 m	0.90 m, sliding doors	MR



3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Required	45nos	MR
		ABC,CO ₂	Provided	MR
		Required	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system- Not required but provided			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	DG Set	MR
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System - Not required but provided			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants - Not required but provided			
	Size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	01	Provided	MR
	Hose Box	01	Provided	MR

✓

12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 			
	Discharge of main Pump	N/A	N/A	N/A
	Head of Main pump	N/A	N/A	N/A
	Number of main pumps	N/A	N/A	N/A
	Jockey Pump out put	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Standby Pump out put	N/A	N/A	N/A
	Standby Pump Head	N/A	N/A	N/A
	Auto Starting/ Manual stopping	N/A	N/A	N/A
	Pump House Access	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Terrace level 			
	Discharge of pump	900 LPM	Provided 2 Nos. 450 & 180 lpm	MR
	Head of the pump	40 m	70 m & 70m	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000Ltr	10,000 Ltrs Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication In lift Car	N/A	N/A	N/A
	Fireman's Grounding Switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	320 kv	MR

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the school were checked and found functional at the time of inspection. The Shortcomings issued vide letter no F6/MS/DFS/School/2014/431 dated 20/02/14 have been rectified. An affidavit from the principal of the school has been submitted as required and the same is placed opposite flagged at 'A'.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to issue fire safety certificate under rule 35 of the Delhi Fire Service rules 2010. Accordingly DFA is put up for perusal and sign.pl.

Signature of the Inspecting Officer

20 (Month) on need rest

21/5/2014