

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

Fax:23412593 E-mail:cfohq.dlfire@nic.in

No F6/DFS/MS/GH/2014/NDZ/689 Dated 05/06/14

FIRE SAFETY CERTIFICATE

Certified that the Hotel Hari Kripa Heritage 9938-B Opp Sarai Rohilla Railway Station New Rohtak Road, New Delhi which comprises of Basement lying vacant, ground floor Reception & lobby, Mezz 04 Guest rooms & 01 Private room, 1st to 3rd floors 08 Guest rooms at each & terrace 2 temporary shed rooms (sealed) was granted NOC by this deptt. vide letter No. F6 / DFS / MS / GH / 2011 /847 dated 10.05.2011 with 28 Guest rooms. The premises was re-inspected by the officer concerned of this department on 27.05.2014 in the presence of Mr. Harish and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of Residential building sub division A-1 Lodging Rooming (Guest House for 28 Guest Rooms) with effect from05/06/14.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, (printed overleaf.)

Issued on.....05/06/14..... at New Delhi by.


(DR.G.C.MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph. 23414333

Copy to :-

1. Hotel Hari Kripa Heritage 9938-B
Opp Sarai Rohilla Railway Station New Rohtak Road, New Delhi
2. The Joint Commissioner of Police (Lic)
1st floor PS Defence Colony New Delhi

Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. Any deviation, with regard to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basements shall be used as per BBL.
6. This Fire Safety Certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier of the building shall, under clause 38 of the DFS Rules, declare in Form "K" every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

- 117 -

INSPECTION REPORT

1. Name & address of the building: Hotel Hari Kripa Heritage 9938-B,
Opp. Sarai Rohilla Railway Station,
New Rohtak Road, New Delhi.
2. Building is comprised of : Basement, Ground + Mezz + 3 Upper
Floors, Terrace 2 staff Rooms in
Temporary shed (sealed) (Total 28
Guest Rooms)
3. Type of Occupancy : Residential (Guest House)
4. Type of Case : Renewal
5. Details of Previous NOC: F6/DFS/MS/GH/2011/847 dated 10-5-2011
6. Fire Safety directive letter No : NA
7. Date of Inspection : 27.05.2014
8. Name of the Inspecting officers : Div. Officer Gurmukh Singh
9. Name and designation of Officer:
from the building side : Sh. Harish (Prop.)
10. Year of Construction : 2001
12. Applicant's letter No : 17634/Jt.CP/Lic.(H) dated 24.04.2014

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Existing Requirement	Provided at Site PSS	Remarks MR/NMR
1	Access to building			
	• Road width	NA	4.5 Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	1No	1No	MR
	• Basement	1 No	1 No	MR
	B. Width of Staircases			
	• Upper Floor	80 CM.	1.14 Mtr	MR
	• Basement	80 CM.	1.5 Mtr	MR
	c. Protection of exits	NA	NA	NA

h

	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	e. No. of continuous staircases to terrace	1 No	1 No	MR
	g. Width of Corridor	1.0Mtr.	1.0 Mtr.	MR
	h. Door Size	1.0Mtr.	1.0 Mtr.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types 	12 Nos.	14 Nos.	MR
		Wco2 & Co2	Wco2, ABC & Co2	MR
	<ul style="list-style-type: none"> • ISI marking 	Required	Provided	MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers at each floor • Length of hose reel hose • Nozzle diameter 	1 No	1No	MR
		30 mtr	30 mtr	MR
		5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Hooter's location 	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • upper floor • sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • size of riser/down-comer • Number of hydrants per 	NA	NA	NA
		NA	NA	NA

Handwritten signature

- N/B -

	floor			
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	33Mtr.	33Mtr.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 Ltrs.	5,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			

lm

14/10

	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the **NOC issued vide letter no.F6/DFS/MS/GH/2011/847 dated 10.5.2011**, renewal under rule 35 of the Delhi Fire Service Rules 2010, is recommended.

Gurmukh Singh
2/6/14
Name Gurmukh Singh

Designation DO (CD)

DY CEO (NDZ)

