

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/school/2014/02/680

Dated: 06/06/2014

FIRE SAFETY CERTIFICATE

Certified that Remal Public School, Block-A, Pocket-2, Sector-3, Rohini, Delhi-110085 comprised of Ground + One upper floor owned/occupied by Remal Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2010/2083 dated 14/07/2010. The premises was re-inspected by the officer from this department on 26/05/2014 in the presence of Sh. Rohit Bajaj and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education letter dated 17/01/2005 issued by Director of Education / NBC- Part IV and verified by the officer concerned of Fire Service and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 06/06/2014 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 06/06/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dfire@nic.in

**Copy to:**

1. The Principal, Remal Public School, Block-A, Pocket-2, Sector-3, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi

N-7

**INSPECTION REPORT**

1. Name & address of the building : Remal Public School, Block-A, Pocket-2, Sector-3, Rohini, Delhi-110085
2. Type of Occupancy : **Educational** (G + 1)
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2010/2083 dated 14/07/2010
5. Fire Safety directives letter No : Director of Education`
6. Date of inspection : 26/05/2014
7. Name of the Inspecting Officers : DO (NW) S. S. Tuli
8. Name and designation of officers  
from the building side : Sh. Rohit Bajaj
9. Year of Construction : 2006
10. Applicant's letter No. : RPSS/14-15 dated 29/04/2014

**Plot Area- 800 Sq.mtr. Covered Area-266.34 Sq.mtr. No of Student- 75 Class Room-8**

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	M/R ✓
	• Gate width	Accessible	Accessible	M/R ✓
	• Width of internal road	--	--	--
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	M/R ✓
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case ✓
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	--	--	--
	f. Door Size	Old case	Old case	Old case ✓

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	05	05	M/R
	<ul style="list-style-type: none"> <li>• Types</li> </ul>		ABC	M/R
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Yes	M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	One at each floor	P	M/R
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	P	M/R
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	P	M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	N/A	N/A	N/A
8	<b>MOEFA</b>	R	P	M/R
9	<b>Public Address System.</b>	R	P	M/R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	N/A	N/A	N/A

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	02	P	M/R
	• Hose Box	02	P	M/R
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	900 LPM	P	M/R
	➤ Head of Main pump	40 m	P	M/R
	➤ Number of main pumps	02	One main pump & one jockey pump	M/R
	➤ Jockey Pump out put	180 LPM	P	M/R
	➤ Jockey pump head	40 m	P	M/R
	➤ Standby Pump out put	--	--	--
	➤ Standby Pump Head	--	--	--
	➤ Auto Starting/ Manual stopping	R	P	M/R
	➤ Pump House Access	R	P	M/R
	• Terrace level			
	➤ Discharge of pump	--	--	--
	➤ Head of the pump	--	--	--
	➤ Power Supply	--	--	--
	➤ Auto Starting of pump	--	--	--
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	50,000 ltr	50,000 ltr	M/R
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	3500 ltr	3500 ltr	M/R
15	<b>Exit Signage.</b>			
		R	P	M/R
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>			
		R	P	M/R

18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20 *	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F-6/DFS/MS/2010/2083 dated 14/07/2010** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
30/5/14  
DO (NW)