

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52/673

Dated: 02/06/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Sant Nirankari Public School** located at 20-B Block, Tilak Nagar, New Delhi-110018 is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/2011/1406 dated 01.07.2011. The School building was re- inspected by the officer concerned of this department on 19.05.2014 in the presence of Smt. Anita Nayyar (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....02/06/14.....at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Headmistress,
Sant Nirankari Public School,
20-B Block, Tilak Nagar, New Delhi-110018.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Ground floor plus one upper floor

N/4

(Renewal)

INSPECTION REPORT

1. Name & address of the building: Sant Nirankari Public School, 20-B Block, Tilak Nagar, Delhi-110018
2. Type of Occupancy: Educational
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. F6/DFS/MS/2011/1406 Dated 01/07/2011
5. Fire Safety directives letter No: _____
6. Date of inspection: 19/05/2014
7. Name of Inspecting Officer: ADO Sandeep Duggal
8. Name and designation of officers:
From the building side: Mrs Anita Nayyar (Manager)
9. Year of Construction: 2005
10. Applicant's letter No.: SNPS/TN/2011-2012 dated 21/04/2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p>	<p>9mtr</p> <p>370cms</p> <p>—</p>	<p>MR</p> <p>—</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>02 NO^s</p> <p>—</p>	<p>03 NO^s</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>1.5mtr</p> <p>—</p>	<p>125, 125 & 100 cms</p> <p>—</p>	<p>MR (Being odd case)</p> <p>No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		—	01	—
	e. Width of Corridor	—	240 cms	—
	f. Door Size	—	98 cms	MR (Being odd case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>Natural Ventilation</p>	<p>No Basement</p> <p>MR</p>

SAN

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	08 No's ABC/CO2 ISI marked	Provided do do	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	one provided do	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping 			

San

Sant Nirankari Public School, 20-B Block, Tilak Nagar,
 N/6 New Delhi - 110018

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		—	220 lpm	MR
		—	40 mtr	MR
		—	—	—
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	250 lhp	MR
15.	Exit Signage.	—	—	—
16.	Provision of Lifts:			No lift
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17.	Standby power supply	—	9am 40kVA	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

Sant

N/7

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. FC/DFS/MS/2011/1406 dated 01/07/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Sandeep
27/5/14
Signature of Inspecting Officer
Name Sandeep Duggal
Designation Asstt. Divisional officer

~~Signature of Inspecting Officer~~
~~Name~~
~~Designation~~

Do (SD)

Renewal F.S.C. for Gti school bldg. is put up for signature, if approved pl.