

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/school/2014) NO2/674

Dated: 02/06/14

FIRE SAFETY CERTIFICATE

Certified that the Arvind Bharti Public School at H-Block, New Ganga Vihar, Delhi-94, owned/occupied by Arvind Bharti Public School, comprised of ground plus one upper floor was issued FSC vide letter no. No.F.6/DFS/MS/2010/3413 dated 23.12.2010. The school building was inspected by the officer concerned of this department on 15.05.2014 in the presence of Sh.Bindu Sharma (Principal) of school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from 02/06/14 for a period of three years, subject to conditions printed overleaf.

Issued on 02/06/14 at New Delhi by

  
(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

copy M

To,  
The Principal  
Arvind Bharti Public School  
H-Block, New Ganga Vihar, Delhi-94,

Copy to:-  
The Dy. Director of Education  
B-Block, Yamuna Vihar, Delhi -53.

**- Conditions -**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : Arvind Bharti Public School at H-Block,  
New Ganga Vihar, Delhi -94.

2. Building is comprised of : Ground +1, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/2010/3413 dated 23.12.10
6. Fire Safety direction letter No : F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11
7. Date of Inspection : 15.05.2014
8. Name of the Inspecting officers: DO Virendra Singh
9. Name and designation of Officer:  
from the building side : Sh.Bindu Sharma (Principal)
10. Year of Construction - : 1994
11. Applicant's letter No : dated 15/04.2014

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	Road width	06 Mtrs.	10 Mtrs.	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	Number of Staircases			
	Upper Floor	01 Nos (one)	02 Nos.	MR
	Basement	N/A	N/A	N/A
	B. Width of Staircases			
	Upper Floor	1.5 M	2 No. of 1M each	MR
	Basement	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	Fire check door	N/A	N/A	M
	5 Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to Terrace	1 no.	1 No.	MR
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	Fire check door	N/A	N/A	N/A
	Sealing of electrical shafts	N/A	N/A	N/A
	Fire rating of shaft door	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	Basement	N/A	N/A	N/A
	Upper floor	N/A	N/A	N/A
5	Fire Extinguisher			
	Total numbers	04 Nos.	04 Nos.	MR
	Types	ABC & Co2	ABC & Co2	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	Length of hose reel hose	N/A	N/A	N/A
	Nozzle diameter	N/A	N/A	N/A



7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
15	• Overhead Tank capacity	N/A	N/A	N/A
16	Exit Signage.	N/A	N/A	N/A
17	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
18	Standby power supply	N/A	N/A	N/A
	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A

2/4

20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A
----	--	-----	-----	-----

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/2010/3413 dated 23.12.10 renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended.

Virendra Singh  
23/5/14

Signature of the Inspecting Officer

Name:-Virendra Singh

Designation:-DO(ED)