

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52/672

Dated: 02/06/14

**FIRE SAFETY CERTIFICATE**

Certified that the building of **M.D. Convent School** located at A-29 & 30, Gulab Bagh, New Delhi-110059 is comprised of ground floor only was issued NOC by this department vide letter No.F.6/MS/DFS/2006/1450 dated 03.07.2006. The School building was re- inspected by the officer concerned of this department on 19.05.2014 in the presence of Sh. Shyam Vashist (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... 02/06/14 ..... at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Manager,  
M.D. Convent School, A-29 & 30,  
Gulab Bagh, New Delhi-110059.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110054.

etc  
any

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

# Ground floor only

(Renewal)

## INSPECTION REPORT

1. Name & address of the building: M.D. Convent School, A-29430 Conlab Bakh, UTM Nagar, N.Delhi-59
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. FC/MS/DFS/2036/1450 Dated 03/07/08
5. Fire Safety directives letter No : \_\_\_\_\_
6. Date of inspection : 19/05/2014
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers  
From the building side : Mr Shyam Vashist (Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : MCS/32/2014 dt 01/05/2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt.	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>	01.03.2011		
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	— — —	3.70 cms. 175 cms	50 mtr away from 12 mtr. road (MR being both cases)
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	—	—	← Ground floor only
	• Basements	—	—	← No Basement
	b. Width of staircases			
	• Upper Floor	—	—	← Ground floor only
	• Basements	—	—	← No Basement
	c. Protection of exits			
	• Fire check door	—	—	—
	• pressurization	—	—	—
	d. No. of continuous staircases to terrace	—	—	—
	e. Width of Corridor	—	185 cms	—
	f. Door Size	1 mtr	1 mtr (Single)	MR (AS students less than 45 reach door)
3.	<b>Compartmentation</b>			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	—	No Basement
	• Upper floors	—	—	Ground floor only

		12 a/c per hour	—	—
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	02 No's ABC & CO <sub>2</sub> ISI marked	04 No's provided provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	— 30 m 5 mm	— — —	— — —
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	— — — — —	— — — — —	— — — — —
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	— — —	— — —	— — —
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	— — —	— — —	— — —
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	— —	— —	— —
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual stopping</li> </ul> </li> </ul>	— — — — — — — —	— — — — — — —	— — — — — — —

*Sain*

M.D. Convent School, A-29 & 30 Conlab Bagh,  
 Uttam Nagar, NDelhi-110059

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
<b>15.</b>	<b>Exit Signage.</b>	—	—	—
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
<b>17.</b>	<b>Standby power supply</b>	—	—	—
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

(Ground floor only)

San

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. FG/MS/DFS/2006/1450 dated 03/07/2006 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note :- School Building is comprised of ground floor only. There is single door of 1mtr width in each class. There are less than 45 students in each class as per undertaking given by manager placed on C-13. FSC is recommended for renewal please.

Sandeep  
21/5/2014.

Signature of Inspecting Officer

Name

Sandeep Duggal

Designation

Asst. Divisional Officer

Signature of Inspecting Officer

Name

Designation

DO (for)

Renewal F.S.C. for ground floor school bldg. is put up for kind approval please.

K. Lomer  
21/5/14