

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. *F6/DFS/MS/PW/2014/52/626*

Dated: *21/5/14*

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Madaan Fireworks** located at shop No.168 & 213, Gorund Floor, Chhoti Subzi Mandi, Tilak Nagar, New Delhi-110018 is comprised of Ground floor only and the fireworks shop will run at ground floor only owned/occupied by M/s Madaan Fireworks (Smt. Promila Madaan) have complied with the guide lines issued by Delhi Police under Delhi Police Act and verified by the officers concerned of fire service on 23.04.2014 in the presence of Sh. Sunil Madaan and that the building / premises is fit for occupancy class Group F mercantile building Sub Division F-1 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....*21/5/14*..... at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Following fire safety directives must be adhered to –

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The NOC is for fire works only.

Copy to:-

1. The Joint. Commissioner of Police (Lic.)  
1<sup>st</sup> floor, P.S., Defence Colony, New Delhi.  
(Ref. No. (PFW/09)/2014/14195-98/Joint CP/Lic(Expl), Dated 26.03.2014)
2. Smt. Promila Madaan,  
H.No-3/16, Moti Nagar, New Delhi-15.

**GRANT OF NOC FOR SALE/STORAGE OF FIRE WORKS**

(In areas other than walled city and congested areas)

**INSPECTION REPORT (PART-A)**

(To be filled by the Inspecting Officers)

1. Name and Address of the licensee : Smt. Promila Madaan R/o H.No 3/16, Moti Nagar, New Delhi-110015.
2. Name & Address of the licensed Premises : M/s Madaan Fireworks, Shop No. 168 & 213, G.F, Chhoti Subzi Mandi, Tilak Nagar, N.D.
3. License No. and validity period : New Case
4. Authority by which license was issued last : \_\_\_\_\_
5. Name and designation of the inspecting officers : D.O S.K. Tomar & A.D.O Sandeep Duggal
6. Date and time of inspection : 23.04.2014 at 15.00 hrs.
7. Period for which license is to be renewed and the authorized quantity : As applied.
8. Name and designation of officers From the building side : Sh. Sunil Madaan
9. Applicant's letter No. : (PFW/09)/2014/14195 98/Joint.CP/Lic. (Expl) dated 26.03.2014 received from Joint. C.P (lic.), Police Station 1<sup>st</sup> Floor, Defence Colony, N.D.

\* NOC is issued subject to the condition that status quo shall be maintained and the conditions laid down under Indian Explosive Rules 1983/ conditions laid down by MCD/ Police are complied with.

**INSPECTION PERFORMA (PART - B)**

(TO BE FILLED IN TRIPLICATE BY THE INSPECTING OFFICERS)

DATE: 23.04.2014

TIME: 15.00 hrs

S.NO.	POINT OF INSPECTION	NORM AS PER GUIDELINES/ VR COMMITTEE REPORT	REMARKS OF THE INSPECTING OFFICER
1.	Type of construction and floor area and floor level	1. Minimum floor area 9m <sup>2</sup> 2. Pucca construction. 3. Premises not under staircase/ means of exit. 4. Business permissible only at ground floor. 5. business from pavement of road is prohibited.	Complied do do do do
2.	Entrance & exit to the licensed premises	The licensed premises shall have Independent entrance and exit.	Complied
3.	Type and distance of Surrounding risk	The premises shall be situated at a distance of 15m from any such premised used for similar explosive/ Inflammable of hazardous materials.	Complied
4.	Nature of business run in	The premises in which fire works are	Intends to use for

5.	Type of Electrical wiring and electrical fittings.	1. Preferably concealed or through conduit 2. The electrical fittings should be flame/ spark proof.	Complied  Complied
6.	Extension of shop for business	Prohibited.	Complied
7.	Approach road	The road width on the sides of which Premises is located should be 12m	Complied
8.	Fire Protection arrangements 1. Extinguishers (type& No.) 2. Sand/ water Buckets. 3. Water Drum	1. All the extinguishers shall have ISI mark. 2. No. of fire extinguishers & type shall be in accordance with the risk & area of the premises. 3. Minimum 2 buckets each of sand & water shall be provided.	Complied  04 ABC type  Complied
9.	No Smoking Board	-----	Complied


The applicant intend to start the trade of sale and possession of fire works at the ground floor. The building comprised of ground floor only. The shop in question is having area 11.1 sq. mtr approx (4.87 x 2.28 mtr) is accessible by 05 mtr wide internal road of DDA market and abuts on 12 meter road, 14 mtr away from the shop in question.

The above said fire safety equipments were checked/operated and the performance found functional at the time of inspection. In view of above the said premises may be consider safe from fire safety point of view for the grant of Fire Safety Certificate for license of the sale and possession of the fireworks.

Accordingly DFA is placed in the file for your perusal, approval and signature please.

  
K. Tomer  
BISTM

Signature of Inspecting Officer  
Designation

  
Sandeep  
05/05/14

Signature of Inspecting Officer  
Designation