

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2014/402/725

Dated: 13/06/14

**FIRE SAFETY CERTIFICATE**

Certified that the Bikanervala Restaurant running at FF, F -116 & 117, of a building comprising of ground plus three upper floors named Aditya Arcade, Community Centre, Preet Vihar, Delhi-92, owned/occupied by M/s Bikanervala Foods Pvt.Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 20.05.2014 in the presence of Sh.Mohan Saili (Manager) and found that the building is fit for occupancy Group -D Assembly building( Restaurant) with effect from ..12/04/14. for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on..... 13/06/14 .....at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

To,  
The Dy.Health Officer  
East Delhi Municipal Corporation  
Health Department, Karkardooma,  
North Zone, Shahdara, Delhi.

Copy to:-  
M/s Bikanervala Foods Pvt.Ltd.  
A-28, Lawrence Road, Industrial Area,  
New Delhi -110035.

O/c  
f

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/3

1. Name & address of the building : Bikanervala Restaurant, at FF, F -116 & 117, Aditya Arcade, Community Centre, Preet Vihar , Delhi-92
2. Building Comprised of : Ground + three upper floors
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives No : Delhi Fire Service Act, 2007 and Rules 2010.
6. Date of Inspection : 23/05/2014
7. Name of the Inspecting Officer : ADO Suresh Singh
8. Name of the designation of Officer  
From the building side : Sh.Mohan Saili (Manager)
9. Year of Construction : 2001
10. Applicant's letter No : Dated 11/04/2014

	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"><li>Road width</li></ul>	12 Mtrs	18 Mtrs.	MR
	<ul style="list-style-type: none"><li>Gate width</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Width of internal road</li></ul>	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"><li>Upper Floor</li></ul>	01 Nos	02 Nos.	MR
	<ul style="list-style-type: none"><li>Basement</li></ul>	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"><li>Upper Floor</li></ul>	1.5 M	1.5 M & 1.0 M	MR
	<ul style="list-style-type: none"><li>Basement</li></ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"><li>Fire check door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Pressurization</li></ul>	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 Mtr.	2.0 M & 1.0 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"><li>Fire check door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Sealing of electrical shafts</li></ul>	Required	Sealed	MR
	<ul style="list-style-type: none"><li>Fire rating of shaft door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Water curtain</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Fire Dampers</li></ul>	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"><li>Basement</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Upper floor</li></ul>	Required	Provided	MR
5.	Fire Extinguisher			
	<ul style="list-style-type: none"><li>Total numbers</li></ul>	05 nos.	06 Nos.	MR
	<ul style="list-style-type: none"><li>types</li></ul>	ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"><li>IS marking</li></ul>	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			

N/4

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• basement	N/A	N/A	N/A
	• upper floors	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	0 no.	0 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 & 180 LPM	MR
	➤ Head of the Pump	40 M	40M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A

N/S

19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Singh*  
*25.5.19*

Signature of the Inspecting Officer

Name: Suresh Singh  
Designation: ADO (Shah)

DO (ED)