

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2014/WZ/709

Dated: 11/6/2014

**FIRE SAFETY CERTIFICATE**

Certified that Govt. Boys Sr. Secondary School, D-Block, Mangol Puri, Delhi-110083 comprised of Ground + One Upper Floor owned / occupied by Govt. Boys Sr. Secondary School has already been issued fire safety certificate vide letter no. F.6/DFS/MS/2011/717 Dated 21/04/2011. The premises was re-inspected by the officer from this department on dated 27/05/2014 in the presence of Sh. M. S. Kaushik (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education dated 01/03/2011 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 11 / 6 /2014 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 11/6/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, Govt. Boys Sr. Secondary School, D-Block, Mangol Puri, Delhi-110083
2. The Director of Education, Old Secretariat, Delhi

M-5

One Block - G Floor + First Floor

**INSPECTION REPORT**

1. Name & address of the building: Govt Boys Sr. Sec. School, D-Block  
 2. Type of Occupancy: Mangal Kuri - Delhi 83 Educational  
 3. Type of Case: New Case / Renewal  
 4. Details of previous NOC: F-6/DPS/ms/2001/717 dt 21-4-11  
 5. Fire Safety directives letter No: Circular of the director of Edu.  
 6. Date of inspection: 27-5-14  
 7. Name of the Inspecting Officers: N.P. Sharma A.D.O.  
 8. Name and designation of officers  
 from the building side: Sh. M.S. Kaushik (Principal)  
 9. Year of Construction: 2007  
 10. Applicant's letter No.: GBSSS/D/MP-45 dt-02-5-14

Plot area: 4000sqm Covered area: 2375sqm No.'s of students: 822 No's of classrooms: 42

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	P	MR
	• Upper Floors	04	04	MR
	• Basements	-	-	-
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5mtr	1.5 mtr each	MR
	• Basements	NA	NA	NA
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1. mtr	1. mtr	MR

M-6

3	<b>Compartmentation.</b>	NIA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	<b>Smoke Management System.</b>	NIA		
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-
5	<b>Fire Extinguishers</b>			
	• Total numbers	10 NOH	30	MR
	• Types	ISI marked	ABC + water CO2	MR
	• IS marking		yes	MR
6	<b>First-Aid Hose Reels.</b>	NIA		
	• Total numbers on each floor		-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7	<b>Automatic fire detection and alarming system.</b>	NIA		
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8	<b>MOEFA</b>	-	-	-
9	<b>Public Address System.</b>	-	-	-
10	<b>Automatic Sprinkler System.</b>	NIA		
	• Basement	-	-	-
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11	<b>Internal Hydrants</b>	NIA		
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-

12	<b>Yard Hydrants.</b>	NIA		
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13	<b>Pumping Arrangements.</b>	NIA		
	• Ground Level	-	-	-
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/ Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	• Terrace level	-	-	-
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power Supply	-	-	-
	➤ Auto Starting of pum	-	-	-
14	<b>Captive Water Storage for fire fighting.</b>	NIA		
	• Underground tank capacity	-	-	-
	➤ Draw-off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	-	-	-
15	<b>Exit Signage.</b>	-	-	-
16	<b>Provision of Lifts.</b>	NIA		
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	<b>Standby power supply</b>	-	-	-

M-8

18	<b>Refuge Area.</b>	N/A		
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	<b>Fire Control Room</b>	N/A		
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. D.F.S./M.S./2011/717 Dated 21/04/2011 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended. F-6/

Signature of the Inspecting Officer  27514

Name N.P. SHARMA

Designation A D O R,

Signature of the Inspecting Officer

Name

Designation

