

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2014/ 102/753

Dated: 19/6/17

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Kanya Vidyalaya**, at **Shiv Ram Park, Nangloi, New Delhi** comprised of **Ground + One upper floor** only owned / occupied by **Govt. Sarvodaya Kanya Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with Director of Education **Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011** and verified by the officer concerned of Fire Service on **11.03.2014** in presence of **Smt. Renu Nigam (Vice Principal)** and that the building / premises is fit for occupancy class (Group B) **Educational** with effect from19/6/17.....for a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 19/6/17 **at New Delhi by.**


(SANTOKH SINGH)
CHEF FIRE OFFICER.
Phone:-23414250

9c Ak

Copy to :-

1. The Vice Principal, Govt. Sarvodaya Kanya Vidyalaya, Shiv Ram Park, Nangloi, New Delhi.
2. Director of Education, Old Secretariat, Delhi-110054.

INSPECTION REPORT

1. Name & address of the building: Govt. Sarvodaya Kanya
Vidyalaya, Shiv Ram Park, Nangloi,
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Letter No N-1
5. Fire Safety directives Letter No. : DOE circular No 3298-3398 dt
11/3/11
6. Date of inspection : 11/6/2014
7. Name of the Inspecting Officer : Ashok Kumar Jaiswal
8. Name and designation of Officer
from the building side : Renu Nigam (vice Principal)
9. Year of Construction : 2012
10. Applicant's letter No. : GSKV/SRP/Ngl/60/dated 22/5/14

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / DOE Cir. dt 1-3-11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Gate width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	<u>1</u>	<u>2</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	b. Width of staircases			
	• Upper floors	<u>1.50 Mtr.</u>	<u>1.50 x 2</u>	<u>MR</u>
	• Basements			
	c. Protection of exits			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>NA</u>
	d. No of continuous staircase to terrace	<u>1</u>	<u>2</u>	<u>MR</u>
	e. Width Of Corridor	<u>1.00 Mtr.</u>	<u>1.50 Mtr.</u>	<u>MR</u>
	f. Door Size	<u>1.00 Mtr.</u>	<u>1.10 Mtr.</u>	<u>MR</u>
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			<u>NR</u>

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour		
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour		NR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	5	5	MR
	<ul style="list-style-type: none"> Types 	ABC/CO ₂	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 			
	<ul style="list-style-type: none"> Length of hose reel hose 		NR	
	<ul style="list-style-type: none"> Nozzle diameter 			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector 			
	<ul style="list-style-type: none"> Location of Main Panel 			
	<ul style="list-style-type: none"> Location of Repeater Panel 			NR
	<ul style="list-style-type: none"> Alternate source of power 			
	<ul style="list-style-type: none"> Hooters' Location 			
8.	MOEFA			NR
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 			
	<ul style="list-style-type: none"> Upper Floor 			
	<ul style="list-style-type: none"> Sprinkler above false ceiling 			NR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 			
	<ul style="list-style-type: none"> Number of hydrants per floor 			NR
	<ul style="list-style-type: none"> Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 			
	<ul style="list-style-type: none"> Hose Box 			NR

13.	Pumping Arrangements	
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	
14.	Captive water Storage for fire fighting	
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	
15	Exit Signage	
16.	Provision of Lifts	
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	
17.	Standby power supply	

18.	Refuge Area			
	➤ Total area			NA
	➤ Location			
19.	Fire control room			
	➤ Detector system panel			NA
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;			NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~



AK Jaiswal
17/6/14

Signature of the Inspecting Officer

Signature of the Inspecting officer

Officer

Name :- Ashok Kumar Jaiswal

Name

Designation :- A.D.O. (Jwalapuri)

Designation

CFD/665
17/6/14