

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/EH/2014/W2/619

Dated: 20/05/14

FIRE SAFETY CERTIFICATE

Certified that the **Haldiram's** located at **Anchor No.103, 125, 126, 127 D Mall, Ground & First Floor, Netaji Subhash Place, Pitampura, Delhi – 110034** was issued FSC vide Letter No. **F6/DFS/MS/EH/2010/969** dated 31-03-2010. The premises was re inspected by the officers concerned of this department on 28-03-2014 in the presence of Mr. Ghanshyam Chaudhary (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 20/05/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/05/14..... at New Delhi by.

  
(Santosh Singh)  
Chief Fire Officer  
Ph: 011 – 23414250

Copy to:

1. Sh. Udit Awasthi (Authorised Signatory),  
Haldiram's Products Pvt. Ltd.,  
Plot No. 70, Pvt. No. A – 55,  
KLJ Complex II, Shivaji Marg, Moti Nagar,  
New Delhi – 110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

### INSPECTION REPORT

1. Name & address of the building: Haldiram's, Anchor No.103, 125, 126, 127, Ground & First Floor, D Mall, Ground Floor, Netaji Subhash Place, Pitampura, Delhi – 110034.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situated in Mall already issued NOC vide letter no. F6/DFS/MS/2012/2059 dated 06-06-2012)
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2010/969 dated 31-03-2010
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 28-03-2014
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer  
from the building side : Sh. D N Thakur (Senior Manager)
9. Year of Construction : 2010
10. Applicant's letter No. : Nil dated Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	30m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	NA	NA
		12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	02 nos. each type DCP & CO2 ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	1 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke Required NA Required Required	Provided Provided at GF NA Provided Provided at entrance	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Not Required Required Required	NR Provided Provided	NR MR MR
11.	Internal Hydrants: <b>Common with the mall</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm 1 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements: <b>Common with the mall</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> </ul>	NA NA NA NA NA	Common with the mall Common with the mall Common with the mall Common with the mall Common with the mall	MR MR MR MR MR

	➤ Standby Pump out put	NA	Common with the mall	MR
	➤ Standby Pump Head	NA	Common with the mall	MR
	➤ Auto Starting/Manual stopping	NA	Common with the mall	MR
	➤ Pump House Access	NA	Common with the mall	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the mall	MR
	➤ Head of the pump	40 m	Common with the mall	MR
	➤ Power supply	Required	Common with the mall	MR
	➤ Auto starting of pump	Required	Common with the mall	MR
14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	Common with the mall	MR
	➤ Draw off connection	NA	Common with the mall	MR
	➤ Fire service inlet	Required	Common with the mall	MR
	➤ Access to tank	NA	Common with the mall	MR
	• Overhead Tank capacity	10, 000 litres	Common with the mall	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2010/969 dated 31-03-2010 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

*Mukesh Verma 3/5/14*

Name

*MUKESH VERMA*

Designation

*ADD (MN)*

Signature of the Inspecting Officer

Name

Designation

