

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/2014/ 221 754

Dated: 19/6/14


**FIRE SAFETY CERTIFICATE**


Certified that the **Karan Public School**, at **C-530, Aman Vihar, Kirari, Suleman Nagar, Delhi-86** comprised of **Ground + One upper floor** only owned / occupied by **Karan & Savitri Educational Society** have complied with the fire prevention and fire safety requirements in accordance with Director of Education **Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398** dated **01/03/2011** and verified by the officer concerned of Fire Service on **28.05.2014** in presence of **Sh. Panchu (Caretaker)** and that the building / premises is fit for occupancy class (Group B) **Educational** with effect from ..... 19.6.14 ..... for a period of 3 (three) years subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The class rooms shall not have more than 45 students in any case.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**Issued on** 19/6/14 **at New Delhi by.**

  
**(SANTOKH SINGH)**  
**CHEF FIRE OFFICER.**  
**Phone:-23414250**



**Copy to :-**

1. The Manager, Karan Public School, C-530, Aman Vihar, Kirari, Suleman Nagar, Delhi-86.

**INSPECTION REPORT****(G+1 upper floor only)**

1. Name & address of the building: **Karan Public School, C-530, Aman Vihar,**  
**Kirari, Suleman Nagar, Delhi-86.**
2. Type of Occupancy : **Educational**
3. Type of Case : **New**
4. Details of previous NOC : Letter No **Nil**
5. Fire Safety directives Letter No. : **DOE Circular No. 3298-3398 Dated 1.03.2011**
6. Date of inspection : **28.05.2014**
7. Name of the Inspecting Officer : **Ashok Kumar Jaiswal**
8. Name and designation of Officer  
from the building side : **Panchu (Caretaker)**
9. Year of Construction : **2013**
10. Applicant's letter No. : **Nil dated 12/05/2014**

S No	Minimum standards on fire prevention and fire safety U/R 33	<b><u>DOE Circular 1.3.2011</u></b> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr	i) 1.65 X 1 ii) 1.25 X 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.00 Mtr.	1.60 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.25 Mtr.	MR

N12

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	5	6	MR
	• Types	ABC/CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR
	• Upper Floor / GF	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR

F2/652  
16/6/14

14

11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level / Over Head			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	NR	NR	NR
15	Exit Signage	Required	Provided	MR

Kaxan Public School, c-530, Aman vihar  
 Kirari Suleman Nagar, New Delhi - 110086

N/A

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010.



*Ashok Kumar Jaiswal*

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

*CFB/652  
16/6/14*

*247/pd-cw  
9/6/14*

*D.O. (CO) [Signature] 9/6*

*DY I.P.O.  
CFB kantar  
9/6*

*DFA N. [Signature] 16/6*

*F.T m-scull [Signature] 16/6/14*