

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Tel:- 011-23414000

No. FG/DFS/MS/2014/SZ/717

Dated: 12/6/14

FIRE SAFETY CERTIFICATE

Certified that the Lotus Automobiles (for storage of petroleum product of IOC Ltd.) located at Kh. No. 76/26, M.G.Road, New Delhi - 110030 comprised of **ground plus one upper floor** was granted FSC by this department vide letter No.F5/(3A)/DFS/MS/2011/194 dated 16/08/11 . The premises was inspected by the officer concerned of this department on 06/06/14 in the presence of **Mr. Joginder singh** and found that the said service station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group J Hazardous Building(Filling Station)** with effect from 12/6/14 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 12/6/14-----at New Delhi by.


(Dr. G.C.Misra)
Chief Fire Officer

o/c  (BOP)

Copy to:-

Sh. Rajender Kumar
Lotus Automobiles,
Kh. No. 76/26, M.G.Road,
New Delhi - 110030

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

Name & address of the building:- Lotus Automobiles, Kh. No. 76/26, M.G.Road, New Delhi – 110030.

Type of occupancy:- Group J Hazardous Building, Filling Station

Type of case:- Renewal

Details of previous NOC:- No. F5/(3A)/DFS/MS/2011/194 dated 16/08/11

Fire safety directives No.- N/A.

Date of inspection:- 06-06-2014

Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)

Name & designation of officer from the building side:- Mr. Joginder Singh

Year of construction:- 2004

Applicant's letter No:-Nil dated 19/05/14

Building is comprised of ground plus one upper floor..

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building	Required	Provided	MR
	1) Road width	Required	Approachable	MR
	2) Gate width	Required	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	01	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.2 mtrs.	Provided	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	20 Nos.	MR
	2) Types		ABC, Co2 & Foam	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	30 m	N/A	N/A
	3) Nozzle diameter	5 mm	N/A	N/A

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level	N/A	N/A	N/A
	Discharge of main pump	N/A	N/A	N/A
	Head of main pump	N/A	N/A	N/A
	Number of main pump	N/A	N/A	N/A
	Jockey pump out put	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Stand by pump output	N/A	N/A	N/A
	Stand by pump head	N/A	N/A	N/A
	Auto starting/Manual stopping	N/A	N/A	N/A
	Terrace level	N/A	N/A	N/A
	Discharge of pump	N/A	N/A	N/A
	Head of pump	N/A	N/A	N/A
	Power supply	N/A	N/A	N/A
	Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	Under ground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	Pressurization of lift shaft	N/A	N/A	N/A
	Pressurization of lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Fireman's switch	N/A	N/A	N/A
	Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	D.G. Set	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A

219

19.	Fire Control Room	N/A	N/A	N/A
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Battery backup	N/A	N/A	N/A
	Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR
	Fire Buckets filled with sand, 'No smoking boards' were found displayed in Hindi & English. No loose electric wiring was seen in the premises.			

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F5/(3A)/DFS/MS/2011/194 dated 16/08/11. renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.

Signature of the inspecting officer



Name: D.B.Mukherjee

Designation: Assistant Divisional Officer (BCP)