

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *F6/DFS/MS/school/2014/M02/759*

Dated: *20/06/14*

FIRE SAFETY CERTIFICATE

Certified that the Presentation Convent Sr. Secondary School, S.P.Mukherjee Marg, Delhi-110006 , comprises of Ground plus three upper floors, was granted NOC by this department vide letter No. F6/DFS/MS/2011/596, dated 06-04-11. The premises was re-inspected by the officers concerned of this department on 13-6-2014 in the presence of Sr. Regi Joseph (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Educational with effect from *20/06/...*2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on. *20/06/...* 2014 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No. 011-23414333

Copy to:-,

1. Principal,
Presentation Convent Sr. Secondary School,
S.P.Mukherjee Marg, Delhi-110006.
2. Dy. Director of Education(North),
Lukhnow Road, Timarpur,
Delhi.

etc

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Presentation Convent Sr. Secondary School,
S.P.Mukherjee Marg, Delhi-110006.
2. Building is comprised of : G+3(Main building),G+1(Admn.block).
3. Type of Occupancy : Education
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/2011/596, dated 06.04.11.
6. Fire Safety direction letter No : No.262-362, dated- 17.01.2005.
7. Date of Inspection : 13.06.14
8. Name of the Inspecting Officers: : Gurmukh Singh (DO) & Vedpal (ADO)
9. Name and designation of Officer
from the building side : Sr. Regi Joseph (Principal)
10. Year of Construction : 1973, 1984, 1989-1990.
11. Applicant's letter No : Letter dated 31.05.14


S.No	Minimum Standards on fire prevention and fire safety as per circular No.262-362, Dated 17.01.2005	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	5m	5m.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	4nos.+2nos.	4nos(main building)+2 nos.in admn.block.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	2.2m, 1.5m, 1.5, 1.10m. (1.5m&1m in admn.block.)	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01no.	2nos.inmainbuilding&1no. in admn.block.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.


5.	Fire Extinguisher			
	Total numbers	40 nos.	40 nos.	MR
	types	CO ₂ & ABC	ABC Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.	Required	Provided	MR
	Total numbers of each floor	02nos.	02nos.	MR
	Length of hose reel hose	30m	30m	MR
	Nozzle diameter	5. mm	5. mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	stage of auditorium	Required	Provided	MR
11	Internal Hydrants			
	size of down-comer	100mm	100mm	MR
	Number of hydrants per floor	02nos.	02nos.	MR
	Hose Box	02nos.	02nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	02+1+(1Jockey)	2+1+(1Jockey)	MR
	➤ Discharge of pump	2=450, 1=220,	2=450, 1=220,	MR
	➤ Head of the Pump	1=180LPM	1=180LPM	
	➤ Power supply	40m(All)	40 (All)	MR
	➤ Auto Starting of pump	Required	Provided	MR




14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50000Ltrs.	50000Ltrs.	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000+5000 liters	35000Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not Required	Provided	MR
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/2011/596, dated 06.04.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.


Signature of the Inspecting Officer
Name : Gurmukh Singh
Designation: DO(Central)


Signature of the Inspecting Officer
Name : Vedpal
Designation : ADO