

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in

No F 6 / DFS / MS / GH / 2014 / 1402/714

Dated 11/06/14

FIRE SAFETY CERTIFICATE

Certified that the M/s Quote Restaurant (A unit of BSK Hospitality Pvt. Ltd.) 44, Regal Building, 2nd floor, Connaught Place, New Delhi comprises of Ground floor + 02 upper floors occupied by (A Unit of BSK Hospitality Pvt. Ltd.) Restaurant running at 2nd floor + Mezzanine floor have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of the fire service on 06/06/2014 in the presence of Sh. Rajesh Arora and found that the said building / premises is fit for occupancy **Class Group D Assembly Building** with effect from 11/06/2014 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11/06/14..... at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi fire Service
Ph - 011-23414333

Copy to:-

1. M/s Quote Restaurant (A unit of BSK Hospitality Pvt. Ltd.) 44, Regal Building, 2nd floor, Connaught Place, New Delhi.
2. Medical officer of Health, Health Department (NDMC), Palika Kendra, New Delhi - 110001 No.D-189 MOH/CSI(Lic.)SI-1 dated 20/03/2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

H/A

INSPECTION REPORT

1. Name & address of the building : M/s Quote Restaurant (A unit of BSK Hospitality Pvt. Ltd.), 44, Regal Building, 2nd floor, Connaught Place, New Delhi.
2. Type of Occupancy : Assembly (Restaurant) Gr+2nd + Mezzanine floor, Restaurant at 2nd floor + Mezzanine floor
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 12/04/2014
- 7 Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer from the building side : Sh. Rajesh Arora (Manager)
9. Year of Construction : old Heritage Bldg.
10. Applicant's letter No. : No. D-189 MOH/CSI (Lic.)SI-1 dated 20/03/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	12 Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.0 & 1.5 Mtr.	1.14 & 1.16 Mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			

MUM

MUM 1.41 Mtr

h

mesh

	• Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2.0 Mtr.	2.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	10 Nos.	12 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	• Basements	NA	NA	NA

h

Mem

H/4,

		Required	Provided	MR
	Upper Floor			
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	100 MM	NA
	• Number of hydrants per floor	NA	01	NA
	• Hose Box	NA	01	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	30 Mtr.	30 Mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting	NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 Ltr.	10,000 Ltr.	MR

h

mur

HPS


15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, FSC is recommended please.



Name :- Sh. Gurmukh Singh
Designation :-DO(CD)



Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)