

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/2014/102/1711

Dated: 11/6/2014

FIRE SAFETY CERTIFICATE

Certified that Shreesainath Education Society, Kh. No 215, 214/1 & 212, Mungesh pur, Delhi-110039 comprised of Ground + First Floor owned/occupied by Shreesainath Education Society have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 23/05/2014 in the presence of Sh. Yogender Kumar (Chairman) and that the building / premises is fit for occupancy of Educational building with effect from 11/6/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 11/6/14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Shreesainath Education Society, Kh. No 215, 214/1 & 212, Mungesh pur, Delhi-110039
2. The Director of Education, Old Secretariat, Delhi

N-1

Gr + one.

INSPECTION REPORT

1. Name & address of the building: Shree Sainath Education Society, Kh No. 215, 214/1, 212, Mungeeshpur, Delhi-39
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal
4. Details of previous NOC : NIL
5. Fire Safety directives letter No : Dir. of Education
6. Date of inspection : 23.5.14
7. Name of the Inspecting Officers : ADD (BW)
8. Name and designation of officers from the building side : Sh. Yogendra Kumar Chairman
9. Year of Construction : 2013
10. Applicant's letter No. : SES/MIGC/14-15/4 dt. 6.5.14

Plot area: 2533.24 sqm Covered area: 1570.54 sqm No.'s of students: NIL No.'s of classrooms: 8
6 room for other purpose

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu. Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MR</u> ✓
	• Gate width	<u>-do-</u>	<u>-do-</u>	<u>MR</u> ✓
	• Width of internal road	<u>-do-</u>	<u>-do-</u>	<u>MR</u> ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>01</u>	<u>01</u>	<u>MR</u> ✓
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	b. Width of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>1.50 mtr</u>	<u>1.53 mtr</u>	<u>MR</u> ✓
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>R 1.50 mtr</u>	<u>1.75 mtr</u>	<u>MR</u> ✓
	h. Door Size	<u>Hall Doors 2-1.50 mtr each</u> <u>CR-Door 1 mtr</u>	<u>2-1.75 mtr each</u> <u>1 mtr</u> <u>Double Doors</u>	<u>MR</u> ✓

N-2

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	13 ABC ISI marked	13 ABC yes	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	N/A	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			

14
34

12	Yard Hydrants.	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		N/A	
14	Captive Water Storage for fire fighting.	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 		N/A	
15	Exit Signage.				
16	Provision of Lifts.	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 		N/A	
17	Standby power supply				

N-4

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

N/A

The fire protection systems provided in the building were test checked and found functional at time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 2 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....N/2.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

DO (AW)

Designation

ADD (B)