

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in


No F 6 / DFS / MS / GH / 2014 / M02/510

Dated 24/04/14

FIRE SAFETY CERTIFICATE

Certified that the **Swati Hostel, Mandir Marg, New Delhi** comprises of Basement + Ground floor + Mezzanine floor + 3 upper floor (A-3(C) was granted NOC by this department vide letter No. F6/MS/DFS/2005/HR/2506/CON/HV/425 dated 14-07-2005. The premises was re-inspected by the officer concerned of this department on 12-04-2014 in the presence of Sh. Anil Kumar Saha Fire Officer (NDMC) and found that the said hostel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub-Division A-1(ii) hostel rooms with effect from 24/04/2014 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on24/04/14..... at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333


Copy to:-

1. Swati Hostel, Mandir Marg, New Delhi.
2. Sh. Anil Kumar Saha Fire Officer (NDMC) Palika Kendra, New Delhi
Letter No. 713/Fire/D Dated 24/03/2014.



Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.


24/4/14
309975

N/5

INSPECTION REPORT

1. Name & address of the building : Swati Hostel, Mandir Marg, New Delhi.
2. Type of Occupancy : Residential (Hostel) B+Gr.+Mezzanine+3floors (A-3(C))
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2005/HR/2506/CON/HV/425 dated 14/07/2005
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 12/04/2014
- 7 Name of the Inspecting Officer : Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Sh. Anil Kumar Saha Fire Officer (NDMC)
- 9 Year of Construction : 2004
10. Applicant's letter No. : No. 713/Fire/D dated 24/03/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 Mtr.	16 Mtr.	MR
	• Gate width	4.5 Mtr.	5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 No.	1 No.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.25 Mtr.	1.30 Mtr.	MR
	• Basements	1.25 Mtr.	0.80 & 1.30 Mtr.	MR
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1 No.	1 No.	MR

merh

N/6

	e. Width Of Corridor	1.25 Mtr.	2.0 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	Mechanical	MR
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	12 Nos.	16 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	• Basements	Required	Provided	MR
	• Upper floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			

Meh

N/7

	<ul style="list-style-type: none"> • Size of riser/down- comer 	100 MM	100 MM	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	01	01	MR
	<ul style="list-style-type: none"> • Hose Box 	01	01	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	01	01	MR
	<ul style="list-style-type: none"> • Hose Box 	01	01	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level 			
	<ul style="list-style-type: none"> • Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> • Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> • Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> • Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> • Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> • Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> • auto Staring/Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> • Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> ○ Terrace level 	02	02	MR
	<ul style="list-style-type: none"> • Discharge of pump 	450 LPM each	450 LPM each	MR
	<ul style="list-style-type: none"> • Head of the pump 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> • Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> • Auto starting of pump 	Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity 	50,000 Ltr.	50,000 Ltr.	MR
	<ul style="list-style-type: none"> • Draw of connection 	NA	Provided	NA
	<ul style="list-style-type: none"> • Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> • Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000 ltr.	10,000 ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA

Merit

N/8

	<ul style="list-style-type: none"> • Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Batter backup 	Required	Provided	MR
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC,Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/2005/HR/2506/CON/HV/425 dated 14/07/2005 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DO (CD)

Sh. M. K. Sharma
22/11/14

marsh
21/11/14
Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)

FIRE SERVICE