

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO.F.6/DFS/MS/School/WZ/ 2014/ 736

Dated: 16/06/2014

**FIRE SAFETY CERTIFICATE**

Certified that the The Modern School, ECNCR Delhi, Gate no-1, Deepali Enclave, Pitam Pura, (Run by Value Educational Society) Delhi-110034 comprised of Ground + Two upper floor owned/occupied by Value Educational Society have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education / NBC- Part IV and verified by the officer concerned of Fire Service on 30/05/2014 in the presence of Mrs. Neelam Puri and that the building / premises is fit for occupancy of Group Class B (Educational) building with effect from 16/06/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 16/06/14 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

**Copy to:**

1. The Principal, Modern School, ECNCR Delhi, Gate no-1, Deepali Enclave, Pitam Pura, (Run by Value Educational Society) Delhi-110034
2. The Director of Education, Old Secretariat, Delhi-110054.



1/2

**INSPECTION REPORT**

1. Name & address of the building : The Modern School, ECNCR Delhi, Gate no-1, Deepaji Enclave, Pitam Pura, Delhi-110034
2. Type of Occupancy : Educational (G + 2)
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Direction of Education
6. Date of inspection : 30/05/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers from the building side : Mrs. Neelam Puri
9. Year of Construction : 2014
10. Applicant's letter No. : Nil dated 17/04/2014

PA- 800 Sq.mtr                      CA-795 Sq. mtr                      NOS- 145                      CR-16

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	M/R
	• Gate width	Accessible	Accessible	M/R
	• Width of internal road	--	--	--
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.5 mtr each	M/R
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	--	--	--
	h. Door Size	01 mtr	Provided with door frame	M/R

2/N


3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	One @ 300 m each  ISI marked	<b>02 at each floor</b>	<b>M/R</b>
	• Types		<b>ABC</b>	<b>M/R</b>
	• IS marking		<b>Yes</b>	<b>M/R</b>
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One at each floor  30 m 5 mm	<b>P</b>	<b>M/R</b>
	• Length of hose reel hose		<b>P</b>	<b>M/R</b>
	• Nozzle diameter		<b>P</b>	<b>M/R</b>
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N
9	<b>Public Address System.</b>	<b>NR</b>	<b>P</b>	
10	<b>Automatic Sprinkler System.</b>			
	• Basement	N/A	N/A	
	• Upper Floor	N/A	N/A	
	• Sprinkler above false ceiling	N/A	N/A	

4/2/0  
6/8

11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NR	P	---
	• Number of hydrants per floor	NR	P	---
	• Hose Box	NR	P	---
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	R	P	M/R
	• Terrace level			
	➤ Discharge of pump	450 LPM	P	M/R
	➤ Head of the pump	40 m	P	M/R
	➤ Power Supply			
	➤ Auto Starting of pump			
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltr	10000 ltr	M/R
15	<b>Exit Signage.</b>	R	P	M/R

4/W.

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>			
		N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>			
		N/A	N/A	N/A



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

*Depto (NW)*  
*...*

Signature of the Inspecting Officer

Name

Designation

*[Signature]*  
*3/8/14*  
*DO (NW)*

*CF/...*