

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F.6/DFS/MS/2014/NDZ/707

Dated: 11/6/14

FIRE SAFETY CERTIFICATE

Certified that the Wood Apple Residency located at Plot No.03, Hargovind Enclave, Vikas Marg Extn., Delhi-92, owned/occupied by M/s Wood Apple Residency, comprised of basement (Storage), Stilt floor (Parking), Mezzanine floor (Reception+ 3 guest room), First floor to third floor (06 guest rooms at each floor), total 21 guest room was granted NOC vide letter no. F.6/DFS/MS/GH/2010/3262 dated 26.11.2010. The building was inspected by the officers concerned of this department on 23.05.2014 in the presence of Dr. Ashish Mittal, and found that the guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group A "Guest House Building" with effect from 11/6/14..... for a period of three years, subject to conditions printed overleaf.

Issued on 11/6/14..... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Ph. 011-23414333

To,  
M/s Wood Apple Residency  
Plot No.03, Hargovind Enclave,  
Vikas Marg Extn., Delhi-92,

Copy to:-  
The Joint Commissioner of Police (Lic.)  
1<sup>st</sup> Floor, Police Station, Defence Colony,  
New Delhi.

1. Name & address of the building : Wood Apple Residency, 3, Hargovind Enclave, Delhi-92.
2. Building is comprised of : Basement + Stilt floor + Mezzanine + First+ Second+third Floor
3. Type of Occupancy : Residential
4. Type of Case : Renewal
5. Details of Previous NOC : Letter no. F6/DFS/MS/GH/2010/3262 dated 26.11.10
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 23.05.14
8. Name of the Inspecting Officers: : Virendra Singh (DO)& ADO Suresh Singh
9. Name of the designation of Officer  
from the building side : Dr.Ashish Mittal
10. Year of Construction : 2010
11. Applicant's letter No : dated 27.03.14

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	6 m	30 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	a. Number of Staircases			
	Upper Floor	1 no.	1 no.	MR
	Basement	1 no.	2 no.	MR
	B. Width of Staircases			
	Upper Floor	1.25 m	1150 mm as accepted earlier	MR
	Basement	1.25 m	1150 mm, 2.3 m	MR
	c. Protection of exits			
	Fire check door	N.A	N.A	N.A.
	Pressurization	N.A	N.A	N.A.
	e. No. of continuous staircases to terrace	01 no.	01 no.	MR
	N.A	N.A	N.A	N.A.
	g. Width of Corridor	1 m	1 m	MR
h. Door Size				
3	<b>Compartmentation.</b>			
	Fire check door	N.A	N.A	N.A.
	Sealing of electrical shafts	N.A	N.A	N.A.
	Fire rating of shaft door	N.A	N.A	N.A.
	Water curtain	N.A	N.A	N.A.
	Fire Dampers	N.A	N.A	N.A.
4	<b>Smoke Management System.</b>			
	Basement	30a/c per hour	N.A	N.A
	Upper floor	12 a/c per hour	N.A	N.A
5.	<b>Fire Extinguisher</b>			
	Total numbers	10 no.	10 no.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	01 no.	01 no.	MR
		30 m	30 m	MR
	Length of hose reel hose	5 mm	5 mm	MR
	Nozzle diameter			
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A	N.A	N.A

8	MOEFA	N.A	Provided	MR
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	1 no.	1no.	MR
	Hose Box per floor	1 no.	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	Ground Level	N.A	N.A	N.A
	Discharge of main Pump	N.A	N.A	N.A
	Head of Main Pump	N.A	N.A	N.A
	Number of main pumps	N.A	N.A	N.A
	Jockey pump out put	N.A	N.A	N.A
	Jockey pump head	N.A	N.A	N.A
	Standby pump out put	N.A	N.A	N.A
	Standby pump Head	N.A	N.A	N.A
	Auto Starting /Manual stopping	N.A	N.A	N.A
	Pump House Access	N.A	N.A	N.A
	Terrace Level	Required	Provided	MR
	Discharge of pump	450 LPM	450 LPM	MR
	Head of the Pump	40 m	40 m	MR
	Power supply	Required	Provided	MR
	Auto Starting of pump	N.A	N.A	N.A
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	5000 Liters	5000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemer's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	Provided	MR
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A

N-13

20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A
----	--	-----	-----	-----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS/GH/2010/3262 dated 26.11.2010, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Singh  
25/11/14

Signature of the Inspecting Officer  
Name:-Suresh Singh  
Designation: - ADO (Shah)

Virendra  
22/11/14

Signature of the Inspecting Officer  
Name:-Virendra Singh  
Designation: - DO (ED)