

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-1100
Fax: 23412593, Tel:- 011-23414333

No.F6/DFS/MS/23/06/14/52/768

Dated: 23/06/14

FIRE SAFETY CERTIFICATE

Certified that the Barat Ghar at S.L.House, Pancasheel Park, Malviya Nagar Road, New Delhi comprised of stilt, ground and 01 upper floor. Stilt floor- car parking, ground floor- baratghar, first floor- 19 rooms Owned/occupied by Shri Sukhan Lal Memorial Charitable Society (Regd.) was granted FSC by this department vide letter No.F6/DFS/MS/2011/75 dated 14/01/2011. The premises was re-inspected by the officer concerned of this department on 19/06/2014 in the presence of Mr. Mahender Singh and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly(Baratghar)** with effect from ~~23/06/14~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~23/06/14~~ at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

o/c
23/06/14
ADD(BCP)

Copy to:-

1. Dy. Health Officer,
SDMC, South Zone,
Green Park, New Delhi.
2. Shri Sukhan Lal Memorial Charitable Society (Regd.)
Barat Ghar at S.L.House, Pancasheel Park,
Malviya Nagar Road, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Baratghar at S.L.House, Pancasheel Park, Malviya Nagar Road, New Delhi
 2. Type of occupancy:- Assembly (Baratghar)
 3. Type of case: - Renewal.
 4. Details of previous NOC:-No. F6/DFS/ MS/ 2011/75 dated 14/01/2011.
 5. Fire safety directives No.- Nil
 6. Date of inspection:-19/06/2014
 7. Name of the inspecting officer:- D.B.Mukherjee A.D.O.(BCP)
 8. Name & designation of officer From the building side: - Mr. Mahender singh
 9. Year of construction:- 1991-92
 10. Applicant's letter No:- Nil, Dated: 09/05/2014
- Building is comprised of Stilt, Ground + 01 Upper Floor.

Sl.No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	Provided	MR
	2) Gate width	Required	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	Provided 03 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1 m	1.25, 1.15 & 1.5 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required 01	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 m	04 nos. Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	15 Nos.	MR
	2) Types		ABC, CO ₂	MR
	3) ISI marking		Yes	MR

✓

17.	Stand by Power Supply	Yes	Provided DG Set	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection. Earlier the building was comprised of basement, ground and two upper floors but now the basement is filled and closed and ground floor has been converted into stilt floor. Thus the building now comprises of stilt, ground and one upper floor.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures are required under the rules the NOC issued vide letter no F6/DFS/MS/ 2011/75 dated-14/01/2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature If approved.

Signature of the inspecting officer

Name: - D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)

DO (South)

20/6/14