

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52/771

Dated: 23/06/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Education Point Convent School** located at Plot No. 3 & 4, Vikas Nagar, Som Bazar Road, New Delhi-110059 is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/2011/194 dated 02.02.2011 for ground floor only. The School building was re- inspected by the officer concerned of this department on 19.06.2014 in the presence of Sh. Harish Tyagi (Chairman) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... 23/06/14at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

o/c san
23/6/14

Copy to:-

1. The Manager,
Education Point Convent School, Plot No.3 & 4,
Vikas Nagar, Som Bazar Road, New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Ground floor plus one upper floor

(Renewal)

INSPECTION REPORT

1. Name & address of the building: Education Point Convent School, Plot no 34, Vikas Nagar, Som Bazar Road, ND-59
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F6/bps/ms/2011/194 Dated 02/02/11
5. Fire Safety directives letter No : _____
6. Date of inspection : 19-06-2014
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr Harish Tyagi (Chairman)
9. Year of Construction : 2010-2011
10. Applicant's letter No. : EPCS/169/14 dt 30-05-2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible — —	6 mtrs 565 + 530 cms —	MR — —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 No. —	01 No. —	MR No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5 mtr —	155 cm —	MR No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door pressurization 	— —	— —	— —
	d. No. of continuous staircases to terrace	—	—	—
	e. Width of Corridor	—	245 cms	—
	f. Door Size	1 mtr	105 + 105 cms	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	— — — — —	— — — — —	— — — — —
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	—	No Basement
			Natural Ventilation	MR

N/4

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<p>07 Nos ABC/CO₂ ISI marked</p>	<p>08 Nos Provided - do -</p>	<p>MR MR MR</p>
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>30 m 5 mm</p>		
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 			

Scm

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.	—	—	—
16.	Provision of Lifts.			No diff)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/6

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DPS/MS/2011/194 dated 02/02/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Sandeep
19/06/2014
Signature of Inspecting Officer
Name Sandeep Duggal
Designation Asstt. Divisional Officer

~~Signature of Inspecting Officer~~
~~Name~~
~~Designation~~

DO (SW)

Renewal F.S.C for ground plus one upper floor school building is put up for kind approval & signature please.

1
20/06/14