

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


NO. F6/DFS/MS/2014/SZ/ EH/824

DATED: 03/07/14

FIRE SAFETY CERTIFICATE

Certified that the Fire 'N' Ice restaurant at Pankaj Arcade-III, 3rd Floor, Sector-10, Dwarka, New Delhi, was granted NOC by this department vide letter no. F6/DFS/MS/EH/09/2881 Dated 24.9.2009. The premise was re-inspected by officers concerned of this department on 26.6.2014 in the presence of Sh. Davinder (Manager) of the restaurant and found that management have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service , Rules 2010 and that the building is fit for occupancy class D "Assembly building (Restaurant)" with effect from..03./07./14.. for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to condition as printed overleaf.

Issued on ...03/07/14..... at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer
Ph No.011-23414333

Copy To:-

1. DHO/West Zone, Health Department, Municipal Corporation of Delhi, Najafgarh Zone New Delhi.
2. The Manager, M/s Fire 'N' Ice restaurant, 3rd Floor, Pankaj Arcade-III, Sector-10, Dwarka, New Delhi.

ole
GMA

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with a copy of the certificate, six months prior to its expiry.

INSPECTION REPORT				
1	Name & address of the building	M/S Fire'N' Ice Restaurant Pankaj Arcade III, 3rd Floor, Sector-10, DDA Mkt., Dwarka, New Delhi.		
2	Type of Occupancy	Assembly "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	No. F-6/DFS/MS/EH/09/2881 Dated. 24.9.09		
5	Fire safety directives letter No	Nil.		
6	Date of inspection	26.6.2014		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh. Davinder (Manager)		
9	Year of construction	2002	Ground + 3 upper Floors	
		DHO/NGZ/11/443 Dt. 30.5.2014	Restaurant at 3rd Floor	
10	Applicant's letter No.			
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old Case /NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	old case	20 Mtrs.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	old case	1 No.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Old Case	1.17 Mtrs	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One	MR
	e. Width of corridor	old case	1.25 Mtrs.	MR
	f. Door size	2 Mtrs.	2 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	12 a/c per hour	N/A	N/A
	upper floors		Exhaust Fans provided	MR

5	Fire Extinguishers			
	total numbers		4 Nos	MR
	Types		ABC, Co2,	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided at 3rd Fl	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided at 3rd fl.	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450, 180 LPM	450,180 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's lift	N/A	N/A	N/A

2/8

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Provided ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule, renewal of Fire Safety Certificate issued vide letter F6/DFS/MS/EH/09/2881 dated 24.9.2009 is recommended.

Accordingly DFA is put up for approval and signature please.

[Handwritten Signature]
30/6/14

Signature of the Inspecting Officer

Name S.P Bhardwaj

Designation ADO (DWARKA)

Do.SW



Renewal F.S.C. for restaurant at 3rd floor of G+3 storied bldg is put up for kind approval & signature please.

[Handwritten Signature]
1
Kumar
1/1/14