


NO. F6/DFS/MS/2014/ SZ/ 804

DATED: 27/06/14

FIRE SAFETY CERTIFICATE

Certified that the Guru GorakhNath society at Plot No. HAF, Pocket No.3, Sector-7, Phase-1, Dwarka, New Delhi, comprised of ground plus one upper floor owned/occupied by Gurugorakh Nath Society have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service, 2010 and verified by the officers concerned of Fire Service on 31.5.2014 in the presence of Sh. Pankaj Singh site supervisor and that the building is fit for occupancy class D "Assembly building" (Temple) for ground plus one upper floor with effect from 27/06/14 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on 27/06/14..... at New Delhi by


(Dr. GC Misra)
Chief Fire Officer
011-23414333

Copy to,

1. The Jt. Director (L&I) Bldg. DDA Building Section INA Vikas Sadan, New Delhi.
2. The Authorized Signatory, Guru GorakhNath Mandir Nirman Samiti, Plot No. HAF, PocketNo.-03, Sector-7, Phase-1, Dwarka, New Delhi.

Conditions

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire safety equipments shall be maintained in perfect working condition all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularization of unauthorized construction / unauthorized use of land, if any.
6. All comments / directions of the licensing department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' [sub rule (1) of Rule 37]** along with a copy of the certificate, six months prior to its expiry.

N/2
INSPECTION REPORT

1	Name & address of the building	Guru GorakhNath Society, HAF, Pocket-03, Sector-7, Phase-1, Dwarka, New Delhi.		
2	Type of Occupancy	Assembly Building "D" (Temple)		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	F6/DFS/MS/BP/2008/56 Dated.9.1.2008		
6	Date of inspection	31.5.2014		
7	Name of the inspecting Officers :	DO Sanjy Kumar Tomar, ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh.Pankaj Singh(Site Engineer)		
9	Year of construction	2014	B+Ground plus one upper floor	
10	Applicant's letter No.	Nil	16.5.2014	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

1	Access to building			
	1) Road width	Required	60 Mtrs.	MR
	2) Gate width	5 Mtrs.	5.5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements		Sealed	Sealed
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs. & 1 Mtr.	MR
	2. basements	-----	Sealed	Sealed
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	1 No.	1 No.	1 No
	e. Width of corridor	1.25 Mtrs.	1.25 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	N/A

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	N/A	Sealed	Sealed
	upper floors		Natural Ventilation	MR

5	Fire Extinguishers			
----------	---------------------------	--	--	--

6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	1 No.	MR
	Length of Hose reel hose	36 Mtrs.	36 Mtrs.	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	Provided
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	Required	100 MM	MR
	Number of Hydrants per floor	Required	One	MR
	hose Box	Required	One	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements	N/A	N/A	N/A
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450, 180 LPM	450 , 180 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000 Ltrs.	10, 000 Ltrs.	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A

18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Basement has been sealed, as per undertaking submitted by authorized signatory place on file.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.



Signature of the inspecting officer

Name S.P. Bhardwaj

Designation : ADO (Dwarka)