

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Tel:- 011-23414333


NO.F6/DFS/MS/EH/2014/ SZ/767

Dated: 23/06/14


FIRE SAFETY CERTIFICATE

Certified that Habibi Restaurant, (a unit of fashion TV Hospitality Pvt. Ltd) located at third floor of MGF Metropolitan Mall, Saket, NewDelhi-110017, was granted FSC by this department vide letter No.F6/ DFS/ MS/ /EH/2014/SZ/271 dated: 26/02/2014. The premises was re- inspected by the officer concerned of this department on 19/06/14 in the presence of Mr. Kapil Binayaka manager of the restaurant and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly (Restaurant) with effect from 23/06/14 or a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 23/06/14 at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer

O/C  23/06/14
ADD (B.L.P.)

Copy to:

1. Dy. Health Officer,
SDMC, South Zone, Green Park, New Delhi.
2. Ms. Deepali Narula
Habibi Restaurant, (a unit of fashion TV Hospitality Pvt. Ltd)
A-2, District Center, 3rd floor of MGF Metropolitan Mall,
Saket, NewDelhi-110017,

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

n/16

INSPECTION REPORT

1. Name & address of the building : M/s F. Grill & Lounge Restaurant (A unit of Great Moments Hospitality Pvt. Ltd.), third floor of MGF Metropolitan Mall, Saket, New Delhi-110017
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/2010/2926 dated 08-10-2010
5. Fire Safety directives letter No : Delhi Fire Service Act-2007 & Rules 2010.
6. Date of inspection : 27-01-2014
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officers from the building side : Mr. Chiranjiv Gupta, accountant
9. Year of Construction : 2009
10. Applicant's letter No. : nil dated 05-10-2013.

Restaurant is located at third floor of MGF Metropolitan Mall, Saket, New Delhi-110017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	(18) 02 for rest.	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	---	---	---
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 (near rest.)	02	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.5 mts	Provided	MR
3	Compartmentation.			

N/7

	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Provided in Mall	MR
	• Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	05	Provided	MR
	• Types	ABC, CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided in restaurant	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Required (smoke/heat)	Provided	MR
	• Location of Main Panel	Staircase	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided in entire building	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required in mall basement	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required in mall basement	Provided	MR
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided in Restaurant	MR
	• Number of hydrants per floor	01 (for rest.)	Provided	MR

2/8

	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		4500 LPM	Provided in Mall	MR
		70 mts	Provided	MR
		02	Provided	MR
		450 LPM	Provided in Mall	MR
		70 mts	Provided	MR
		4500 LPM	Provided in Mall	MR
		70 mts	Provided	MR
		Required	provided	MR
		Required	Provided for entire mall	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	5,00,000 liters	Provided in Mall	MR
		Required	Provided in Mall	MR
		Required	Provided in Mall	MR
		Required	Provided in Mall	MR
		20,000 liters	Provided in Mall	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch 	Required in Mall	Provided	---
		Required in Mall	Provided	---
		Required in Mall	Provided	---
		Required in Mall	Provided	---

N/9

	• Lift Signage	Required in Mall	Provided	---
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided in Mall	MR
	• Flow Switch Panel	Required	Provided in Mall	MR
	• PA System Panel	Required	Provided in Mall	MR
	• Batter backup	Required	Provided in Mall	MR
	• Building Floor Plans	Required	Provided in Mall	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 CO ₂ type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/EH/2010/2926 dated 08-10-2010, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

~~DD(SY)~~

[Handwritten Signature]
10/2/14

[Handwritten Signature]
15/2/2014



Signature of the Inspecting Officer
Name M.K.CHATTOPADHYAY
Designation: - Asstt. Div. Officer (M.Rd)