

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/School/2014/w2/782

Dated: 24/06/2014

FIRE SAFETY CERTIFICATE

Certified that **Himalaya Public Sr. Sec. School, D-12 Sect.-7, Rohini, Delhi-110085**
Comprised of **Ground + 3 upper floors** owned / occupied by **Himalaya Public Sr. Sec. School**
has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2010/142, dated**
13/01/2010 The premises was re-inspected by the officer from this department on dated
27/05/2014 in the presence of **Sh. Prasana Kumar (Caretaker)**. All the fire prevention & fire
safety arrangements as provided in the premises found in good working condition. The premises
have therefore deemed complied with the requirements of **Circular issued by Director of**
Education letter dated 01/03/2011 and the building / premise is fit for occupancy of **Group**
Class B (Educational) with effect from **24/06/2014** for a period of **three years**, in accordance
with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to
compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 24/06/14 at New Delhi by

424/0
(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Himalaya Public Sr. Sec. School, D-12 Sect.-7, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi

N/7

G.F. + Three upper floors

INSPECTION REPORT

1. Name & address of the building: Himalaya Public Sr. Sec. School (Recog)
D-12, Sector VII, ROHINI, Delhi-85 Educational
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/OPS/MS/2010/142 dt 13-01-2010
5. Fire Safety directives letter No: Director of Edn circular dt 01-3-11
6. Date of inspection: 27-5-14
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers from the building side: Sh. Prassana Kumar (Care-taker)
9. Year of Construction: 2002
10. Applicant's letter No: Fire/H.P.S.S.S/14/ dt 23-4-14

Plot area:- 1.83 Acre Covered area:- 3631.72 mt No.'s of students:- 1550 approx No's of classrooms:- 44

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu ✓ BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	03	03	MR
	• Basements	-	-	-
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5 mtr each	1.5 mtr each	MR
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1. mtr	1.2 mtr	MR

N/S

12

3	Compartmentation.	N/A		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	-	-
4	Smoke Management System.	N/A		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	-	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	one @ 300 ml 17 ISI marked	18 ABC type yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02 at each floor 30 m 5 mm	P P P	MR MR MR
7	Automatic fire detection and alarming system.	N/A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	-	-	-
8	MOEFA	-	-	-
9	Public Address System.	-	-	-
10	Automatic Sprinkler System.	N/A		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	-	-	-
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer ✓ • Number of hydrants per floor • Hose Box 	02 at each floor NR 02 at each floor	P N/A P	MR N/A MR

n/a

Mumabayan Public School.
D-12, Sec-VIII, Rohini

12	Yard Hydrants.	N.A		
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13	Pumping Arrangements.			
	• Ground Level	-	-	-
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/ Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	• Terrace level			
	➤ Discharge of pump	450 lpm + 180 lpm	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	-	-	-
	➤ Auto Starting of pum	-	-	-
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	-	-	-
	➤ Draw-off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	5000 ltr	P	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.	NR	P	NA
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	-	-	-

2/10

18	Refuge Area.	N/A		
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room	N/A		
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer 

Name N.P. Sharma

Designation ADO R1

DO. JW


30/5/14

Signature of the Inspecting Officer 

Name

Designation



460/666
27/6/14