

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F6/DFS/MS/2014/52/802

Dated: 27/06/14

FIRE SAFETY CERTIFICATE

Certified that the Mohan Leela Royal (A Unit of Mittal Hotels Pvt. Ltd.) Banquet Hall located at Ground Floor, A8/3, Wazirpur Industrial Area, Delhi in a building comprised of Basement + Ground + Two Upper Floors owned and occupied by Sh. Sameer Mittal have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 04-06-2014 in the presence of Sh. Sameer Mittal (Owner) and that the building / premises is fit for the occupancy class "Assembly" Group D with effect from 27/06/14.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/06/14..... at New Delhi.

Copy to:-

1. Dy. Health Officer (Civil Lines Zone),
Public Health Department, 16, Rajpur Road,
Delhi - 110054.
2. Sh. Sameer Mittal,
Mohan Leela Royal Banquet Hall,
A8/3, Wazirpur Industrial Area, Delhi.


Santokh Singh
Chief Fire Officer
Delhi Fire Service
E-mail : cfowz.dlfire@nic.in
Phone : 011-23414250

o/c A/216

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. Basement shall be used as per building bye laws.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building : Mohan's Leela Eating House/restaurant at A-8/3, Wazirpur Ind. Area, Delhi (G.F. Banquet hall)
2. Type of Occupancy : Class D (Assembly)
3. Type of Case : New
4. Details of previous NOC : F.6/DFS/MS/EH/2011/1127 dated 08/06/2011 for restaurant
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 04-06-2014
7. Name of the Inspecting Officers : ADO Mukesh Verma
8. Name and designation of officers
- From the building side : Mr. Sameer Mittal
9. Year of Construction : 1990
10. Applicant's letter No. : DHO/CLZ/2014/1898 dated 20-02-2014

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	Provided	M/R
	• Gate width	required	Directly Accessible	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Two	M/R
	• Upper Floors	Two	Two	M/R
	• Basement	Two	Provided	M/R
	b. Width of staircases			
	• Upper Floors	N.A.	N.A.	N.A.
	• Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	one	Provided	M/R
	e. Width of Corridor	required	Open hall	M.R.
	f. Door size	2 x 2.0 mtr	✓ 2.10 m, 1.39 m ✓ 2.14 m, 1.70 m	M.R.
3.	Compartmentation.			
	• Fire check door	N.A.	N.A.	N.A.

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Exhaust fans Provided	M.R
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Provided	M.R.
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	17	Provided	M.R
	<ul style="list-style-type: none"> Types 	ABC -5 kg & CO ₂ 4.5 kg	Provided	M.R
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	M.R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	two	two	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m required	Provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Location of Main Panel 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Alternate source of power 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Hooter's Location 	N.A.	N.A.	N.A.
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	Required	Provided	M.R
10.	Automatic Sprinkler system	Required	Provided	M.R
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	provided	M.R

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	two	provided	M.R.
		two	provided	M.R.
12. Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
13. Pumping Arrangements.				
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
		F.6/DFS/MS/2013/1748	dated 09/07/13	
	Terrace level			
	➤ Discharge of pump	2 pumps= one 450 LPM one 225 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14. Captive Water Storage for fire fighting.				
		F.6/DFS/MS/2013/1748 dated 09/07/13		
	Underground tank capacity			
	➤ Draw -off connection	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank ➤ Overhead Tank Capacity 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		5,000 ltrs	Provided	M.R
15	Exit Signage.	required	Provided	M.R.
16.	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A	N.A.
		N.A.	N.A.	N.A.
		N.A	N.A.	N.A.
17.	Standby power supply	Required	100 KVA	M.R
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N.A	N.A	N.A
		N.A	N.A	N.A
19.	Fire Control Room			
	<ul style="list-style-type: none"> ➤ Detector System Panel ➤ Flow Switch Panel ➤ PA system Panel ➤ Batter backup ➤ Building Floor plans 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer
Mukesh Verma 18/6/24

Signature of the Inspection Officer

Name *MUKESH VERMA*

Name

Designation *ADD (W)*

Designation

DO (West)
ds
19/6