

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS(MS) 2014/805

Dated: 30/06/2014

FIRE SAFETY CERTIFICATE

Certified that Missionaries of Charity (Mother Teresa's Home) on Ground Floor at Majnu Ka Tilla, Timarpur, Delhi-110054 comprised of Basement, Ground and First Floor owned/occupied by Missionaries of Charity, Nirmal Hriday have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 19/06/2014 in the presence of Sister Charmaine and that the building / premises is fit for occupancy of Institutional Building for Ground Floor only with effect from 30/06/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall not be used for any purpose.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 **The FSC is for Ground Floor only. The basement & First Floor will not be occupied.**
- 8 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/06/14 at New Delhi

✓ Copy To:-

Sr. M. Charmaine M.C.
Nirmal Hriday Home,
Magazine Road,
Civil Line, Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dfire@nic.in

INSPECTION REPORT

FSC required for G.F only

1. Name & address of the building : Nirmal Hriday Home, Magazine Road, Civil Line, Delhi
2. Type of Occupancy : Institution Building (B- lying vacant)
3. Type of Case : New Case (G.F- used for destitute)
4. Details of previous NOC : Letter No. Nil Dated: Nil (F.F- used by servants)
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2009/2127 Dated 16/07/2009
6. Date of inspection : 19/06/2014
7. Name of the Inspecting Officers : DCFO (WZ)
8. Name and designation of officers
from the building side : Sister Charmaine
9. Year of Construction : 2009
10. Applicant's letter No. : L.No- nil dated 11/06/2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M.R.
	• Gate width	4.5m	yes	M.R.
	• Width of internal road	N.A	N.A	N.A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N.A	Stairs – 04 Ramp - 01	FSC required for G. F only
	• Basements	N.A	03	N.A
	b. Width of staircases			
	• Upper Floors	N.A	N.A	N.A
	• Basements	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	R	P	M/R
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	N.A	N.A	N.A
	f. Door Size	4 x 1.50 mtr	4 x 1.54 mtr	M.R.

3	Compartmentation.			
	➤ Fire check door	R	P	M.R
	➤ Sealing of electrical shafts	N.A	N.A	N.A
	➤ Fire Rating of shaft door	N.A	N.A	N.A
	➤ Water Curtain	N.A	N.A	N.A
	➤ Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	➤ Basements	30 a/c per hour	P	M.R.
	➤ Upper floors	12 a/c per hour	N.A	N.A
5	Fire Extinguishers			
	➤ Total numbers	One @ 300 m ²	18	M.R
	➤ Types	18 Water Co2, DCP type	ABC	M.R
	➤ IS marking	ISI marked	yes	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	P	M.R.
	• Length of hose reel hose	30mm	yes	M.R.
	• Nozzle diameter	5mm	yes	M.R.
7	Automatic fire detection and alarming system.			
	➤ Type of detectors	N.A	N.A	N.A
	➤ Location of Main Panel	N.A	N.A	N.A
	➤ Location of Repeater Panel	N.A	N.A	N.A
	➤ Alternate source of power	N.A	N.A	N.A
	➤ Hooters' Location	N.A	N.A	N.A
8	MOEFA	R	P	M.R
9	Public Address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	➤ Basement	R	P	M.R
	➤ Upper Floor	N.A	N.A	N.A
	➤ Sprinkler above false ceiling	N.A	N.A	N.A

11	Internal Hydrants			
	➤ Size of riser/down-comer	(4")	P	M.R
	➤ Number of hydrants per floor	(02)	P	M.R
	➤ Hose Box	R	P	M.R
12	Yard Hydrants.			
	➤ Total number of hydrants	N.A	N.A	N.A
	➤ Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey Pump out put	180 LPM	P	M.R
	➤ Jockey pump head	40 m	P	M.R
	➤ Standby Pump out put	N.A	N.A	N.A
	➤ Standby Pump Head	N.A	N.A	N.A
	➤ Auto Starting/ Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace level			
	➤ Discharge of pump	900 LPM	P	M.R
	➤ Head of the pump	40 m	P	M.R
	➤ Power Supply	N.A	N.A	N.A
	➤ Auto Starting of pump	N.A	N.A	N.A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N.A	N.A	N.A
	➤ Draw-off connection	N.A	N.A	N.A
	➤ Fire service inlet	N.A	N.A	N.A
	➤ Access to tank	N.A	N.A	N.A
	• Overhead Tank capacity	20000 Ltr	20000 ltr	M.R
15	Exit Signage.	R	P	M.R

N/10

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A	N.A	N.A
	• Pressurization of Lift lobby	N.A	N.A	N.A
	• Communication In lift Car	N.A	N.A	N.A
	• Fireman's Grounding Switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A
17	Standby power supply	R	32 KVA	M.R
18	Refuge Area.			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	Fire Control Room			
	• Detector System Panel	N.A	N.A	N.A
	• Flow Switch Panel	N.A	N.A	N.A
	• PA System Panel	N.A	N.A	N.A
	• Batter backup	N.A	N.A	N.A
	• Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers 2 (b) and 16.

Note: - FSC is recommended for G.F only as per request received from management vide letter date 12/06/2014

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

keertat
20/6/14

CFo/682
24/6/14