

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2014/ 52/778

Dated: 24/06/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Shaheed Captain Anuj Nayyar Sarvodaya Bal Vidyalaya No-2**, B-Block, Janak Puri, New Delhi -110058 having two blocks namely Old & New Block with one Multipurpose Hall. The Old Block is comprised of ground floor plus two upper floors, the New Block is comprised of ground floor plus one upper floor & the Multipurpose Hall at ground floor only with five exits owned/occupied by The Govt. of NCT of Delhi was re-inspected by the officer concerned of this department on 16.06.2014 in the presence of Sh. Hari Kishan (Vice Principal) and found that the Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on ..24/06/14.....at New Delhi

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to: -

1. The Principal,
SCAN Sarvodaya Bal Vidyalaya No-2,
B-Block, Janak Puri, New Delhi-110058.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Old Block is comprised of Ground Floor plus two upper floors.
 New Block is comprised of Ground Floor plus one upper floor.

N/S.

INSPECTION REPORT

1. Name & address of the building : SCAN Sarvodaya Bal Vidyalaya No-2, B-Block, Tonak Puri, N.D-58.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. _____ Date _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 16.06.2014
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Hari Kishan (Vice Principal)
9. Year of Construction : 1980-81, 2012-13
10. Applicant's letter No. : SCAN/91 dated 30.05.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible - -	09mtr 04mtr -	MR MR -
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Two	Five	MR
	b. Width of staircases			No Basement
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms	200, 152, 155, 128 & 128 cms	MR
	c. Protection of exits			No Basement
	<ul style="list-style-type: none"> • Fire check door • pressurization 	-	-	-
	d. No. of continuous staircases to terrace			-
	e. Width of Corridor		Two	-
	f. Door Size		175cms, 235cms 90cms x 210cms 145cms x 210cms	-
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	-	-
		-	Sealed	-
		-	-	-
		-	-	-
		-	-	-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	-	No Basement
			Natural Ventilation	MR

(1)

N/G

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	20 Nos	Provided	MR
	• Types	CO ₂ , ABC	-do-	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose reel hose	30 m	-do-	MR
	• Nozzle diameter	5 mm	-do-	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	+
	• Location of Main Panel	-	-	+
	• Location of Repeater Panel	-	-	+
	• Alternate source of power	-	-	+
	• Hooters' Location	-	D-G Set of 62.5 kVA	-
8.	MOEFA			
9.	Public Address System			
		-	Provided	-
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M	MR
	• Number of hydrants per floor	-	Two	MR
	• Hose Box	-	-do-	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	Two	MR
	• Hose Box	-	-do-	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

N/8.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The school building having two blocks namely Old Block & New Block with one multipurpose Hall. The Old block is comprised of Ground Floor plus two Upper Floors. The Upper Floors are served by two staircases having width 128 cms each. The New Block is comprised of Ground Floor plus one Upper Floor. The Upper Floor is served by three staircases having width 200cms, 155cms & 152 cms respectively. The multipurpose hall is comprised of Ground Floor only with five exits. FSC is recommended for above said School Building.

Signature of Inspecting Officer

Name P.S. Dahiya

Designation AB&H. Divisional Officer.

Signature of Inspecting Officer

Name

Designation

