

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2014/W2/809

Dated: 30/06/14

FIRE SAFETY CERTIFICATE

Certified that the **Spaghetti Kitchen** located at **Shop No. 8 & 9, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi** was issued FSC vide Letter No. F6/DFS/MS/EH/2011/859 dated 11-05-2011. The premises was re inspected by the officers concerned of this department on 06-06-2014 in the presence of Mr. Abhishek (Restaurant Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 30/06/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/06/14 at New Delhi by.

(Santokh Singh)
Chief Fire Officer,
Ph: 011-23414250

Copy to:

1. Sh. Jaspal Singh Sabharwal (Director),
Premises No. 8 & 9, 2nd Floor, Pacific Mall,
Tagore Garden, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/17

INSPECTION REPORT

1. Name & address of the building: Spaghetti Kitchen located at Shop No. 8 & 9, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situated in Mall already issued NOC vide letter no. F6/DFS/MS/2014/WZ/345 dated 11-03-2014)
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2011/859 dated 11-05-2011
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 06-06-2014
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Abhishek (Restaurant Manager)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil Dated nil

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|------------------|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 6 m | 30m Provided | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | Old Case | Old Case | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | Old Case | Old Case | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |

2/9.

| | | | | |
|-----|--|---------------|----------------------|----|
| | ➤ Pump House Access • Terrace level | NA | Common with the mall | NA |
| | ➤ Discharge of pump | 900 lpm | Common with the mall | MR |
| | ➤ Head of the pump | 40 m | Common with the mall | MR |
| | ➤ Power supply | Required | Common with the mall | MR |
| | ➤ Auto starting of pump | Required | Common with the mall | MR |
| 14. | Captive water Storage for fire fighting: Common with the mall | | | |
| | • Under ground tank capacity | NA | 2,00,000 litres | NA |
| | ➤ Draw off connection | NA | Provided | NA |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | NA | Provided | NA |
| | • Overhead Tank capacity | 10,000 litres | 30,000 Litres | MR |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

CF/6/2014
27/6/14

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2011/859 dated 11-05-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name **MUKESH VERMA**

Name

Designation **ADD (MN)**

Designation

CF/6
Inspector