

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/School/2014/ 52/1773

Dated: 23/06/14

FIRE SAFETY CERTIFICATE

Certified that the **Sri Ram International School** located at Prem Nursery, Gopal Nagar, Najafgarh, New Delhi-110043 having two blocks namely Old Block & New Block (Not in use as stated by Admn. Officer), Old Block is comprised of ground floor plus three upper floors was issued NOC by this department vide letter No.F.6/MS/DFS/2005/2587 dated 15.12.2005. The School building (Old Block only) was re-inspected by the officer concerned of this department on 16.06.2014 in the presence of Sh. Raj Kumar (Transport Incharge) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Old Block only**) is fit for occupancy class Educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....23/06/14..... at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Sri Ram International School,
Prem Nursery, Gopal Nagar, Najafgarh, New Delhi-110043.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110 054.

01 csm
23/6/14

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/8

Ground floor plus three upper floors (old block only)

(Renewal)

INSPECTION REPORT

1. Name & address of the building : Sri Ram International School, Prem Nursery, Gopal Nagar, Najafgarh, Noida-43
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. FG/MS/DFS/2005/2587 Date 15/12/2005
5. Fire Safety directives letter No : _____
6. Date of inspection : 16-06-2014
7. Name of Inspecting Officer : AOO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr Raj Kumar (Transport Incharge)
9. Year of Construction : 2001
10. Applicant's letter No. : SRIS/2014-15/185 dt 23/05/2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>12 mtrs</p> <p>470 cms</p> <p>—</p>	<p>MR</p> <p>MR</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>Two</p> <p>—</p>	<p>Two</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>—</p> <p>—</p>	<p>130 & 125 cms</p> <p>—</p>	<p>MR (old case)</p> <p>No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		<p>—</p>	<p>01</p>	<p>—</p>
	e. Width of Corridor			
		<p>—</p>	<p>135/280 cms</p>	<p>—</p>
	f. Door Size			
		<p>—</p>	<p>Few 1mtrs and rest 93 cms (single)</p>	<p>MR (Being old case Student's letter thanks)</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p>	<p>—</p> <p>Natural Ventilation</p>	<p>No Basement</p> <p>MR</p>

N/9

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	12 Nos	16 Nos	MR
	• Types	ABC/CO ₂	provided	MR
	• IS marking	ISI marked	-do-	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	one	provided	MR
	• Length of hose reel hose	30 m	-do-	MR
	• Nozzle diameter	5 mm	-do-	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8.	MOEFA			
9.	Public Address System			
		—	provided	—
10.	Automatic Sprinkler System			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11.	Internal Hydrants			
	• Size of riser/down-comer	—	100 mm	—
	• Number of hydrants per floor	—	one	—
	• Hose Box	—	one	—
12.	Yard Hydrants			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/Manual stopping	—	—	—

Sam

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		450 Lpm	600 Lpm	MR
		40mH	40 mH	MR
		—	—	—
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	5000 lth	—
		—	—	—
		—	Provided	—
		—	—	—
		5000 lth	10000 lth	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			No lift
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17.	Standby power supply	—	140KVA (DGRT)	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/11

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/2005/2587 dated 15/12/2005 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- School building is comprised of ground floor plus three upper floors having two blocks namely Old Block & New Block. New Block is not in use as per letter given by principal placed on C-30. Old Block's upper floors are approachable by two staircases having width not 125cms. There is single door of 100cms/93cms width in each classroom. There are less than 45 students in each class as per undertaking given by Admn officer placed at C-29. FSC is recommended for renewal please.

Sandeep
19/6/2014

Signature of Inspecting Officer

Name

Sandeep Duggal

Designation

Asst Divisional officer

Signature of Inspecting Officer

Name

Designation



DO (SW)

Renewal F.S.C. for G+3 upper floor school bldg is put up for Kind approval & signature please.

1
23/6/14
504