

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO.F.6/DFS/MS/School/WZ/ 2014/ 800

Dated: 27/06/2014

FIRE SAFETY CERTIFICATE

Certified that Vidya Sthali Public School, Plot no-116, Jain Nagar, Karala, Delhi-110081 Comprised of Ground floor only owned/occupied by Vidya Sthali Public School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 18/06/2014 in the presence of Mrs. Rajni God (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 27 / 06 /2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 27/06/14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Vidya Sthali Public School, Plot no-116, Jain Nagar, Karala, Delhi-110081
2. The Director of Education, Old Sectt. Delhi for information

N-5

Ground floor only

INSPECTION REPORT

- 1. Name & address of the building: Vidya Sathi Public School Plot No. 116
- 2. Type of Occupancy: Educational Jain Nagar Karala Delhi-81
- 3. Type of Case: New Case / Renewal
- 4. Details of previous NOC: N/A
- 5. Fire Safety directives letter No: Dir. of Edu. Cir. No. 13/11
- 6. Date of inspection: 18.6.14
- 7. Name of the Inspecting Officers: AOO (BW)
- 8. Name and designation of officers from the building side: Mrs Rajni Goel.
- 9. Year of Construction: 2003-04 to 2014
- 10. Applicant's letter No.: dt No Hai dt 5.6.14

PA-250sq.yards. CA-175sq.yards. Nos-80 NOCR-6

Minimum Standards on fire prevention and fire safety U/R 33	NBC DOE Requirement	Provided at site	Remarks MR/NMR
1 Access to building			
• Road width	Accessable	Accessable	MR
• Gate width	—	—	—
• Width of internal road	—	—	—
2 Number, Width, Type & Arrangement of Exits			
a. Number of staircases			N/A
• Upper Floors			
• Basements			
b. Width of staircases			
• Upper Floors			
• Basements			
c. Protection of exits			
• Fire check door			
• Pressurization			
e. No. of continuous staircases to terrace			
g. Width of Corridor			
h. Door Size	1 Mtr	1.06 Mtr	MR
3 Compartmentation.			
• Fire check door	—	—	—

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	2 ABC ISI marked	2 ABC YES	MR MR MR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm			
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 				
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 				

13	Pumping Arrangements.		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	<p style="text-align: center;">N/A</p>	
14	Captive Water Storage for fire fighting.		
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<p style="text-align: center;">N/A</p>	
15	Exit Signage.		
16	Provision of Lifts.		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<p style="text-align: center;">N/A</p>	
17	Standby power supply		
18.	Refuge Area.		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		
19	Fire Control Room		
	<ul style="list-style-type: none"> • Detector System Panel 	<p style="text-align: center;">N/A</p>	


H-8

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... NIL



Signature of the Inspecting Officer

Name

Designation DO (N.W) on ECL

D.C.F.O./

256/DCFO/2011

Signature of the Inspecting Officer

Name

Designation

18/6/14

ADD (R/W)