

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

NO. F.6 / DFS / MS / CGHS / 2007 / 1540

Dated. 8/6/2007

To

Sh. L. C. Thakur.  
Ex Engineer (El), El Divn No. 5.  
M.S. House,  
Sector-18, Dwarka, Ph-II,  
New Delhi

Sub:- Regarding issuance of NOC from fire safety point of view in r/o M. S. Houses Sector-18 B. Dwarka, Ph-II, New Delhi.

Sir,


Please refer your letter No. W-151/EE/ELD-5/CB/06/DDA/701 dated 27/4/2007 & Dated 25/5/2007 on the subject cited above. In this regard, it is intimated that the inspection of above premises has been inspected by the team of officers of this department on 12/5/2007 to see the compliance of the fire safety recommendations communicated to them vide letter No. F.6 / MS / DFS / CGHS / 2001/127 dated 17/1/2001 and also shortcomings communicated earlier vide letter NO. F. 6 / DFS / MS / CGHS / 2007 / 763 Dated 16/3/2007.

During the course of inspection, it is observed that the management has provided the fire safety measures such as U/G water storage tank, O/H water storage tank, Fire pumps, Wet riser system, Hose reels, Hose boxes, P. A System, Yard hydrant, MCP and Portable fire extinguishers etc found in working conditions.

In view of the above, this department has no objection from fire safety point of view and premises can be occupied subject to the following conditions.

1. Providing of fire safety measures does not give any guarantee that there will be NO FIRE. These equipments / installations can minimize the losses if maintained in good working condition and handled efficiently in case of fire.
2. The approach all around the building shall not be used for parking and be kept free for the movement of fire appliances.
3. Any deviation in the building from sanction plans may be verified by the building department.
4. Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.
5. All occupants / security personnel shall be trained to operate the fire safety equipments during emergency.

Yours faithfully

  
Dy. Chief Fire Officer  
For Chief Fire Officer  
Delhi Fire Service

Copy to:-

The Joint Director, (Bldg) (L & I)  
DDA, Vikas Sadan, INA,  
New Delhi.

