

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel: 011-23414333

NO.F6/ DFS/ MS/School/2014/ *52/838*

Dated: *08/07/14*

FIRE SAFETY CERTIFICATE

Certified that, Bloom Public School running at ground floor of a building comprised of basement, ground plus one upper floor located at C-3, Vasant Kunj, New Delhi-110070 owned/occupied by school management was inspected by the officer concerned of this department on 25/06/2014 in the presence of Ms .Anita Ahuja (Principal) and found that the School have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational(School)" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on *08/07/14* at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

etc
27/7/14
ADD (BLO)

Copy to: -

Mr. Manmohan Sharma
Bloom Public School,
C-3, Vasant Kunj, New Delhi-110070

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Bloom Public School, C-3, Vasant Kunj, New Delhi-110070
2. Type of Occupancy : Educational (School)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011.
6. Date of inspection : 26-06-2014
7. Name of the Inspecting Officers : ADO D.B. Mukherjee
8. Name and designation of officers
from the building side : Mr. Manmohan Sharma (Admin. Officer)
9. Year of Construction : 2004
10. Applicant's letter No. : Nil dated: 16/05/2014,

The School is running in the ground floor of a building comprised of Basement, Ground Plus one upper floor)

Sl. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dte. of Edu. Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
a. Number of staircases				
• Upper Floors	N/A	N/A	N/A	N/A
• Basements	N/A	N/A	N/A	N/A
b. Width of staircases				
• Upper Floors	N/A	N/A	N/A	N/A
• Basements	N/A	N/A	N/A	N/A
c. Protection of exits				
• Fire check door	N/A	N/A	N/A	N/A
• Pressurization	N/A	N/A	N/A	N/A
e. No. of continuous staircases to terrace	N/A	N/A	N/A	N/A
g. Width of Corridor	N/A	N/A	N/A	N/A
h. Door Size	N/A	N/A	N/A	N/A

(Handwritten mark)


3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	Required	04 Nos.	MR
	• Types	ABC,CO ₂	Provided	MR
	• IS marking	Required	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA			
		N/A	N/A	N/A
9	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	N/A	N/A
	• Number of hydrants per floor	01	N/A	N/A
	• Hose Box	01	N/A	N/A

Handwritten signature

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection system provided in the school were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules as per the directives of Education Department vide Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011 it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer


30/6/14

Name (D.B.Mukherjee)

Designation :- Assistant Divisional Officer

20/South)

1/7/14