

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel: 011-23414333

NO.F6/DFS/MS/2014/ 52/845

Dated: 08/07/14

FIRE SAFETY CERTIFICATE

Certified that Delhi Karnataka Sangha (R), located at Rao Tularam Marg, Sector-12, R.K.Puram, New Delhi-110022, comprised of basement, ground plus three upper floors, owned/occupied by Delhi Karnataka Sangha was granted NOC by this department vide letter No. F6/DFS/MS/2006/458 dated: 23/02/2006. The premises was re-inspected by the officer concerned of this department on 22/06/14 in the presence of Mr. Balachandran and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Mixed (Business, Assembly & Mercantile) with effect from 08/07/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 08/07/14 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

o/c
7/7/14
ADP(BL)

Mr. C.M. Nagaraja (General Secretary),
Delhi Karnataka Sangha (R),
Rao Tularam Marg, Sector-12, R.K.Puram,
New Delhi-110022

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Delhi Karnataka Sangha (R), Rao Tularam Marg, Sector-12, R.K. Puram, New Delhi-110022
2. Type of occupancy:- Mixed Occupancy (Business, Assembly & Mercantile)
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/2006/458 dated-23/02/2006
5. Fire safety directives No.- F.6/MS/DFS/BP/2003/486 dated 04/03/2003
6. Date of inspection:- 22/06/2014
7. Name of the inspecting officer:- D.B. Mukherjee, A.D.O. (BCP)
8. Name & designation of officer From the building side:- Mr. Balchandra (Manager)
9. Year of construction:- 2005
10. Applicant's letter no:- Nil Dated: 28/04/2014

Building under report is comprised of Basement, Ground Plus Three Upper Floor.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided	MR
	2) Gate width	6 m	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	02	01 & 2 Ramps	MR
	B. Width of staircase			
	1. Upper floors	1.50 m	1.50m each	MR
	2. Basements	1.50 m	1.50m & Ramp 3.5m each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Provided Exhaust Fans	MR
	2) Upper floors	12 a/c per hour	Natural Ventilation	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	20Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			



	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Ground Floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Every Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided	MR
	2) Hose box	Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	Provided	MR
	b) Head of main pump	70m	Provided	MR
	c) Number of main pump	01	Provided	MR
	d) Jockey pump out put	180 LPM	Provided	MR
	e) Jockey pump head	70m	Provided	MR
	f) Stand by pump output	2850 LPM	Provided	MR
	g) Stand by pump head	70 m	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	Required	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 Ltrs.	1,00,000 Ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 Ltrs.	15,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	Fire Control Room			

19	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: Provided			MR

The fire protection system provided in the building were checked and found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/2012/1034 dated: 23/03/2012 have been rectified. In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/2006/458 dated: 23/02/2006, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended. Accordingly DFA is put up for signature please.


Signature of the inspecting officer

 30/6/14

Name :- D.B. Mukherjee.

Designation :- Asstt. Div. Officer (BCP)

DO (South)

 1/7/14