

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52/841

Dated: 08/07/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Ideal Radiant Public School** located at B-26, Shiv Vihar, Vikas Nagar, Uttam Nagar, New Delhi-110059. The building is comprised of ground floor plus two upper floor but the school is running at ground floor only owned/occupied by the school management was inspected by the officer concerned of this department on 26.06.2014 in the presence of Sh. Chandrakant Singh (Manager) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises (**Ground floor only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....08/07/14.....at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Ideal Radiant Public School, B-26,
Shiv Vihar, Vikas Nagar, Uttam Nagar, N.D-59.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

CFC SAN
7/7/14

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Building is comprised of ground floor plus two upper floors
 (School at Ground floor)

(New)

INSPECTION REPORT

1. Name & address of the building: Ideal Rachint Public School, B-26, Shiv Vihar, Vikas Nagar,
2. Type of Occupancy: Educational Uttam Nagar, New Delhi-110059
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. Dated
5. Fire Safety directives letter No:
6. Date of inspection: 26-06-2014
7. Name of Inspecting Officer: ADO Sandeep Duggal
8. Name and designation of officers
From the building side: Mr Chandrakant Singh (Manager)
9. Year of Construction: 201
10. Applicant's letter No.: Nil dated 18-06-2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	4.70 & 4.30m 170 Cms —	MR MR —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	— —	— —	School at Ground floor No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	— —	— —	School at Ground floor No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	— —	— —	— —
	d. No. of continuous staircases to terrace	—	—	—
	e. Width of Corridor	—	170 Cms	—
	f. Door Size	—	90 Cms (single door)	MR (old building & students less than 45 in each class)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	— — — — —	— — — — —	— — — — —
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour — —	— — Natural Ventilation	No Basement School at G floor

Sand

N/S

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 No's ABC/CO2 ISI marked	06 No's Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm		
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System		Provided	
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping 			

San

deal Radiant Public School, B-26, Shiv Vihar, Vikas Nagar, Uttam Nagar, New Delhi-110059

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.	—	—	—
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	— <i>no lift</i>
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/7

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- Building is comprised of ground floor plus two upper floors, but school is running at ground floor only as per the undertaking given by manager placed on C-6. There is single door having width 90cms each in every class room, the manager has given undertaking placed on C-6 that there are less than 45 students in each class & the school building got recognised in year 2008 (Letter No. Sandeep 26/6/14) (copy is placed on C-7). F.S.C. is recommended for school at Ground floor only.

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asst. Divisional Officer

Signature of Inspecting Officer

Name

Designation



Do (sw)

F.S.C. for G+2 floor school bldg (School is running in G+1) only is placed on file for kind approval & signature please

Amur