

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2014/ w2 | 853

Dated: 11/07/14

FIRE SAFETY CERTIFICATE


Certified that the **Jass Ram Convent School** at **E-1/164, 50 Foota Road, Shiv Ram Park, Nangloi, New Delhi-110041** comprised of **Ground + one upper floor** only owned / occupied by **Jass Ram Convent School** has already been issued NOC / FSC by this department vide letter **No. F.6/DFS/MS/2008/1286 dated 05.05.2008**. The premises was re-inspected by the officer concerned of this department on **02.07.2014** in the presence of **Sh. Gaurav Gupta (Manager)** and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by **Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005** and that the building / premises is fit for occupancy class **Educational** (Group B) with effect from **11/07/14**....for a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 11/07/14 **at New Delhi by.**


(SANTOKH SINGH)
CHEF FIRE OFFICER.
Phone:-23414250

o/c 

Copy to :-

1. Sh. Gaurav Gupta (Manager), Jass Ram Convent School, E-1/164, 50 Foota Road, Shiv Ram Park, Nangloi, New Delhi-110041.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

INSPECTION REPORT

- 07/11
1. Name & address of the building: Jass Ram Convent School
E-11164, 50' Road, Shiv Ram
Park, Nangloi, Delhi - 41
 2. Type of Occupancy: Educational
 3. Type of Case: Renewal
 4. Details of previous NOC: Letter No F.6/DFS/MS/2008/1256/5.5.08
 5. Fire Safety directives Letter No. : -----
 6. Date of inspection: 2/7/2014
 7. Name of the Inspecting Officer: A.K. Jaiswal ADO(SWP)
 8. Name and designation of Officer
from the building side: Gaurav Gupta (Manager)
 9. Year of Construction: 2004
 10. Applicant's letter No. : JRCS/NOC/13-14/1/11.6.2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE ^{at 17.01.05} Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	old case	old case	old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	d. No of continuous staircase to terrace	old case	old case	old case
	e. Width Of Corridor	old case	old case	old case
	f. Door Size	old case	old case	old case
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door		NR	
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		NR
5.	Fire Extinguishers			

8. Name and designation of Officer

Gaurav Gupta (Manager)

from the building side :

9. Year of Construction

2004

10. Applicant's letter No. :

JRCS/NOC/13-14/1/11.6.2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE Circle at 17.01.05 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	old case	old case	old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	d. No of continuous staircase to terrace	old case	old case	old case
	e. Width Of Corridor	old case	old case	old case
	f. Door Size	old case	old case	old case
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door		NR	
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		NR
5.	Fire Extinguishers			
	• Total numbers	4	4	MR
	• Types	ISI marked	Provided	MR
	• IS marking	Required	Provided	MR

6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	one	one	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm.	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector 			NR
	<ul style="list-style-type: none"> Location of Main Panel 			
	<ul style="list-style-type: none"> Location of Repeater 			
	<ul style="list-style-type: none"> Panel 			
	<ul style="list-style-type: none"> Alternate source of power 			
	<ul style="list-style-type: none"> Hooters' Location 			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 			NR
	<ul style="list-style-type: none"> Upper Floor 			
	<ul style="list-style-type: none"> Sprinkler above false ceiling 			
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 			NR
	<ul style="list-style-type: none"> Number of hydrants per floor 			
	<ul style="list-style-type: none"> Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 			NR
	<ul style="list-style-type: none"> Hose Box 			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			NR
	<ul style="list-style-type: none"> Discharge of main pump 			
	<ul style="list-style-type: none"> Head of main pump 			
	<ul style="list-style-type: none"> Number of main pumps 			
	<ul style="list-style-type: none"> Jockey pump out put 			
	<ul style="list-style-type: none"> Jockey pump head 			
	<ul style="list-style-type: none"> Standby Pump out put 			
	<ul style="list-style-type: none"> Standby Pump Head 			
	<ul style="list-style-type: none"> Auto Starting/Manual stopping 			
	<ul style="list-style-type: none"> Pump House Access 			
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	220 lpm	450 lpm	
	<ul style="list-style-type: none"> Head of the pump 	40 MH	40 MH	MR
	<ul style="list-style-type: none"> Power supply 	Required	Required	MR

	<ul style="list-style-type: none"> • Location of Repeater 				
	<ul style="list-style-type: none"> • Panel 				NR
	<ul style="list-style-type: none"> • Alternate source of power 				
	<ul style="list-style-type: none"> • Hooters' Location 				
8.	MOEFA				
9.	Public Address System				
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> • Basements 				
	<ul style="list-style-type: none"> • Upper Floor 				
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 				NR
11.	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer 				
	<ul style="list-style-type: none"> • Number of hydrants 				NR
	<ul style="list-style-type: none"> • per floor 				
	<ul style="list-style-type: none"> • Hose Box 				
12.	Yard Hydrants				
	<ul style="list-style-type: none"> • Total number of hydrants 				NR
	<ul style="list-style-type: none"> • Hose Box 				
13.	Pumping Arrangements				
	<ul style="list-style-type: none"> • Ground Level 				
	<ul style="list-style-type: none"> • Discharge of main pump 				
	➤ Head of main pump				
	➤ Number of main pumps				
	➤ Jockey pump out put				
	➤ Jockey pump head				
	➤ Standby Pump out put				
	➤ Standby Pump Head				
	➤ Auto Starting/Manual stopping				
	➤ Pump House Access				
	<ul style="list-style-type: none"> • Terrace level 				
	➤ Discharge of pump	220 lpm	450 lpm		MR
	➤ Head of the pump	40 MH	40 MH		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump	Required	Provided		MR
14.	Captive water Storage for fire fighting				
	<ul style="list-style-type: none"> • Under ground tank capacity 				
	➤ Draw of connection				
	➤ Fire service inlet				
	➤ Access to tank				
	<ul style="list-style-type: none"> • Overhead Tank capacity 	3,000 lts	3,000 lts		MR

N/6

		Required	Provided	MR
15.	Exit Signage			MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby		NR	
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage		NR	
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area			
	➤ Location		NA	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel		NA	
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;		NR	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F.6/DFS/MS/2008/1286/5/5/08 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Ak Jaiswal
21/7/14

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

D.O. / (CO) *[Signature]*
2/7