

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2014/52/828

Dated: 07/07/14

FIRE SAFETY CERTIFICATE

Certified that the **New Rana Public School**, at **479, (Near Shishuwala Talab), Mundka, Delhi-110041**, comprised of **Ground + one upper floor** only owned / occupied by **New Rana Public School**, has already been issued NOC / FSC by this department vide letter No. **F.6/DFS/MS/2010/2262 dated 30.07.2010**. The premises was re-inspected by the officer concerned of this department on **02.07.2014** in the presence of **Smt. Uma Kalra (Principal)** and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by **Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005** and that the building / premises is fit for occupancy class **Educational** (Group B) with effect fromfor a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.

Issued on 07/07/14 **at New Delhi by.**

S
7/7
(SANTOKH SINGH)
CHEF FIRE OFFICER.
Phone:-23414250

Copy to :-

1. Smt. Uma Kalra (Principal), New Rana Public School, 479, (Near Shishuwala Talab), Mundka, Delhi-110041.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

To See the compliance of deptt. Letter No. N/10 G+I

FG/DFS/MS/2014/School/INSPECTION REPORT

1242/G.G.2014

1. Name & address of the building: New Rang Public School, 479
(Near Shishucoal Talab), Mundka
2. Type of Occupancy : Educational Delhi-41
3. Type of Case : Renewal
4. Details of previous NOC : Letter No FG/DFS/MS/2010/2262/30.7.10
5. Fire Safety directives Letter No. : DOE circular dated 17/01/2005
6. Date of inspection : 2/7/2014
7. Name of the Inspecting Officer : A.K. Jaiswal ADO/(JOP)
8. Name and designation of Officer Uma Kaha (Principal)
from the building side :
9. Year of Construction : 2006
10. Applicant's letter No. : Nel dated 23/6/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE give Requirements ^{17.01.05}	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	old case	old case	old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NP	NR
	• Pressurization	NR	NP	NR
	d. No of continuous staircase to terrace	old case	old case	old case
	e. Width Of Corridor	old case	old case	old case
	f. Door Size	old case	old case	old case
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door		NR	
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour		

8. Name and designation of Officer

Uma Kaha (Principal)

from the building side :

9. Year of Construction

2006

10. Applicant's letter No. :

Nil dated 23/6/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE fire Requirements 17.01.05	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided ✓	MR
	• Gate width	Accessible	Provided ✓	MR
	• Width of internal road	NA	NA ✓	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	old case	old case ✓	old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NP	NR
	• Pressurization	NR	NP	NR
	d. No of continuous staircase to terrace	old case	old case ✓	old case
	e. Width Of Corridor	old case	old case ✓	old case
	f. Door Size	old case	old case ✓	old case
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door		NR	
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour	✓	
	• Upper floors	12 a/c per hour	✓	NR
5.	Fire Extinguishers			
	• Total numbers	4	8	MR
	• Types	ISI marked ABC/CO2	Provided ✓	MR
	• IS marking	Required	Provided ✓	MR

6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	One	One	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector 			
	<ul style="list-style-type: none"> Location of Main Panel 			
	<ul style="list-style-type: none"> Location of Repeater 			
	<ul style="list-style-type: none"> Panel 			
	<ul style="list-style-type: none"> Alternate source of power 		NR	
	<ul style="list-style-type: none"> Hooters' Location 			
8.	MOEFA	NR	NP	NR
9.	Public Address System	NR	NP	NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 			
	<ul style="list-style-type: none"> Upper Floor 			
	<ul style="list-style-type: none"> Sprinkler above false ceiling 		NR	
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 			
	<ul style="list-style-type: none"> Number of hydrants 			
	<ul style="list-style-type: none"> per floor 		NR	
	<ul style="list-style-type: none"> Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 			
	<ul style="list-style-type: none"> Hose Box 		NR	
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 			
	<ul style="list-style-type: none"> Head of main pump 			
	<ul style="list-style-type: none"> Number of main pumps 			
	<ul style="list-style-type: none"> Jockey pump out put 			
	<ul style="list-style-type: none"> Jockey pump head 			
	<ul style="list-style-type: none"> Standby Pump out put 			
	<ul style="list-style-type: none"> Standby Pump Head 			
	<ul style="list-style-type: none"> Auto Staring/Manual stopping 			
	<ul style="list-style-type: none"> Pump House Access 			
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	220 lpm	Provided	MR ✓
	<ul style="list-style-type: none"> Head of the pump 	40 MH	Provided	MR

N/12

		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			NR
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area			NR
	➤ Location			
19.	Fire control room			
	➤ Detector system panel			NR
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;			

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. FG/DFS/MS/2262/2010/30.7.10 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Ashok Kumar Jaiswal
21/7/2014

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

D.O. / (cast)
du
3/7

CFo/719
4/7/14

2014/7/14