

No. F.6/DFS/MS/EH/2014/SZ/ 837

Dated: 08/07/14

**FIRE SAFETY CERTIFICATE**

Certified that the M/s The Golden Dragon Restaurant at DDA Market, Panchshel Park, New Delhi, running at 1<sup>st</sup> floor of the building comprised of ground plus one upper floor was granted NOC by this department vide letter No. F6/DFS/MS/EH/2011/1171 dated 26.07.2011. The premises was re-inspected by the officer concerned of Delhi Fire Service on 24.06.2014 in the presence of Sh. Pawan Sachdeva of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from 08/07/14 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 08/07/14..... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer

OK

Copy to: -

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi,
2. The Authorized Signatory, M/s. The Golden Dragon Restaurant (at 1<sup>st</sup> floor), DDA Market, Panchshel Park, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning- Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1	Name & address of the building	M/s The Golden Dragon Restaurant, 1st floor, DDA Market , Panchshel Park, New Delhi.		
2	Type of Occupancy	Assembly Building "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/EH/2011/1171 dated 26.07.2011		
5	Fire safety directives letter No	Nil		
6	Date of inspection	24.06.2014		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj , ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Sh. Pawan Sachdeva		
9	Year of construction	(Restaurant running at 1st floor)		
10	Applicant's letter No.	Nil dated 09.06.2014		Ground plus one upper floor
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old Case (Two Exit)	1 No. stair & 1 Ramp Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	Stair- 0.72 & Ramp 1.25 Mtrs Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Two	1.15, 1.20 Mtrs Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	Exhaust Fans Provided	MR
5	<b>Fire Extinguishers</b>			
	total numbers		4 Nos	MR
	Types		ABC, Water Co2	MR
	ISI marking	ISI	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5MM	Provided	MR

✓

7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
		N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	Old Case	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided (Restaurant)	MR
	hose Box	One	Provided	MR
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 & 180 LPM	Provided	MR
	b. head of the pump	35 Mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	2500 Ltr	5000 Ltr Provided	MR
15	<b>Exit Signage.</b>			
		Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>			
		Required	Provided	MR
18	<b>Refuge Area.</b>			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

**Fire control room**

- a. detector system Panel
- b. Flow switch Panel
- c. PA system Panel
- d. Batter backup
- e. Building floor plans

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A

N/A


20

**Special Fire Protection systems for protection of special risks, if any: N/A**


The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/EH/2011/1171 dated 26.07.2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.



Signature of the Inspecting Officer  
Name D.P. BHARDWAJ  
Designation:- D.O. (South)



Signature of the Inspecting Officer  
Name D.B. Mukherjee  
Designation:- A.D.O. (BCP)