

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/2014/ 82/871

Dated: 17/7/14

**FIRE SAFETY CERTIFICATE**

Certified that the **Avadh Public School** at **E-Block, 40 FT. Road, Prem Nagar-III, Nangloi, Delhi-110086** is comprised of **Ground + One upper floor** only owned / occupied by **Avadh Educational Society (Regd.)** have complied with the fire prevention and fire safety requirements in accordance with Director of Education **Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398** dated **01/03/2011** and verified by the officer concerned of Fire Service on **02.07.2014** in presence of **Sh. Bajrang Sukla (Manager)** and that the building / premises is fit for occupancy class **Educational** with effect from **17/7/14**.....for a period of 3 (three) years subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.

**Issued on** 17/7/14 **at New Delhi by.**

17/7  
(SANTOKH SINGH),  
CHIEF FIRE OFFICER.  
Phone:-23414250

**Copy to :-**

1. Sh. Bajrang Sukla (Manager), Avadh Public School, E-Block, 40 FT. Road, Prem Nagar-III, Nangloi, Delhi-110086.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

N/3  
**INSPECTION REPORT**

G + 1

1. Name & address of the building: Awadh Public School  
E Block, Prem Nagar III, Nangla
2. Type of Occupancy : Educational Delhi-110086
3. Type of Case : New
4. Details of previous NOC : Letter No N/10
5. Fire Safety directives Letter No. : DOE circular dt 1/3/2011
6. Date of inspection : 2/7/2014
7. Name of the Inspecting Officer : A.K. Jaiswal ADO/(JWP)
8. Name and designation of Officer  
from the building side : Bajrang Shukla (Manager)
9. Year of Construction : 2005-06
10. Applicant's letter No. : N/1 Dated 10/6/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE fire dt 1.3.11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.20 Mtr. 93 cm.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NP	NR
	• Pressurization	NR	NP	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.00 Mtr.	1.00 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NR	NP	NR
	• Sealing of electrical shafts	NR	NP	NR
	• Fire Rating of shaft door	NR	NP	NR
	• Water Curtain	NR	NP	NR
	• Fire Dampers	NR	NP	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NP	NP

4. Details of previous NOC : Letter No N/D
5. Fire Safety directives Letter No. : DOE circular dt 1/3/2011
6. Date of inspection : 2/7/2014
7. Name of the Inspecting Officer : A.K. Jaiswal ADO/(JWP)
8. Name and designation of Officer  
from the building side : Bayrang Shukla (Manager)
9. Year of Construction : 2005-06
10. Applicant's letter No. : N/D Dated 10/6/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL DOE circular dt 1.3.11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.20 Mtr. 93 cm.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NP	NR
	• Pressurization	NR	NP	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.00 Mtr.	1.00 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NR	NP	NR
	• Sealing of electrical shafts	NR	NP	NR
	• Fire Rating of shaft door	NR	NP	NR
	• Water Curtain	NR	NP	NR
	• Fire Dampers	NR	NP	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NR	NR
	• Upper floors	12 a/c per hour	NR	NR
5.	Fire Extinguishers			
	• Total numbers	4	6+2	MR
	• Types	ISI marked	Provided	MR
	• IS marking	Required	Provided	MR

N/2

6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>			
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>		NR	
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detector</li> </ul>			
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>			
	<ul style="list-style-type: none"> <li>• Location of Repeater</li> </ul>			
	<ul style="list-style-type: none"> <li>• Panel</li> </ul>		NR	
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>			
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>			
8.	MOEFA		NR	
9.	Public Address System		NR	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>			
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>		NR	
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>			
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>		NR	
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>		NR	
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head		NR	
	➤ Auto Staring/Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump			

	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>			
	<ul style="list-style-type: none"> <li>• Location of Repeater</li> </ul>			
	<ul style="list-style-type: none"> <li>• Panel</li> </ul>			NR
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>			
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>			
8.	MOEFA			NR
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>			
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>			NR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>			
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>			NR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>			NR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			NR
	➤ Auto Staring/Manual stopping			
	➤ Pump House Access			
	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power supply			
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under Ground tank capacity</li> </ul>			
	➤ Draw of connection			
	➤ Fire service inlet			NR
	➤ Access to tank			
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>			

N/3

15	Exit Signage	NR	NP	NR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NP	NR
	➤ Pressurization of lift lobby	NR	NP	NR
	➤ Communication in lift Car	NR	NP	NR
	➤ Fireman's Grounding Switch	NR	NP	NR
	➤ Lift Signage			
17.	Standby power supply	NR	NP	NR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel		NA	
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NP	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010.

*Ak Jaiswal*  
21/7/2014

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (Jwala Puri)

D.O. / (C)

*dh*  
5/7



2024/12/20 (C)