

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No. F6/DFS/MS/GH/2014/402189/

Dated: 18/07/14

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Blue Diamond Guest House, 2562, Sarak Prem Narain, Choori Walan , Delhi-6, comprised of Basement, Ground floor (02 rooms+ reception), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (03 Rooms on each floor), was granted NOC by this department vide letter No. F6/DFS/MS/GH/2011/2350, dated 28-09-2011. The premises was re-inspected by the officer concerned of this department on 15-07-2014 in the presence of Sh. Abdul Wahid (Owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of total 11 guest rooms at ground floor to third floor only with effect from .18/07/2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .18/07/14 at New Delhi by.



(Dr.G.C.Misra)  
Chief Fire Officer  
T.No.011-23414333



Copy to:-

1. The Joint. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049 w.r.t. letter No.22363/Joint. C.P./Lic.(H), dated 11.06.14.
2. M/S Blue Diamond Guest House, 2562, Sarak Prem Narain, Choori Walan,

Delhi-6.

**Conditions for the validity of fire safety certificate are overleaf:-**

H/14

**INSPECTION REPORT**

1. Name & address of the building : M/S Blue Diamond Guest House, 2562, Sarak Prem Narain, Choori Walan, Delhi-06.
2. Building is comprised of : B+G+4,( Guest house is at ground to 4<sup>th</sup> floor,11 rooms )
3. Type of Occupancy : Lodging House
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/GH/2011/1827, dated-04.08.11.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 15.07.2014
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Abdul Whid (Owner)
10. Year of Construction : 1950.
11. Applicant's letter No : No.22363/Joint. C.P./Lic.(H), dated 11.06.14.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks (P.S.S. Area)
1	Access to building			
	Road width	N.A.	5 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size				
	01 no.	01 no.		MR
	N.A.	N.A.		N.A.
	80 cms.	90cms.		MR
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	1no.	1no.		MR
N.A.	N.A.		N.A.	
N.A.	N.A.		N.A.	
3	Compartmentation			
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
4	Smoke Management System.			
Basement Upper floor	30a/c per hour	N.A.		N.A.
	12 a/c per hour	N.A.		N.A.



N/15

M/S Blue Diamond Guest House, 2562, Sarak Prem Narain, Choori Walan, Delhi-6.

5.	Fire Extinguisher			
	Total numbers	08 nos.	08 nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on ground floor only	01no.	01no.	MR
	Length of hose reel hose	30m.	30m.	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	01no.	01no.	MR
	➤ Discharge of pump	225LPM	225LPM	MR
	➤ Head of the Pump	40m.	40m.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	N.A	N.A.	N.A.

W



M/16

M/S Blue Diamond Guest House, 2562, Sarak Prem Narain, Choori Walan, Delhi-6.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	2500Liters.	2500Liters.	MR.
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/GH/2011/1827, dated 04.08.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO

*(Handwritten signature)*  
16/17  
cc + MR