

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/2014/W2/870

Dated: 17/07/14

FIRE SAFETY CERTIFICATE

Certified that the **City Banquet (A Unit of Shree Ganesh Enterprises)** located at Ground Floor, 40 – B, Rama Road, New Delhi – 110015 in a building comprised of Basement + Ground Floor only was issued FSC vide Letter No. F6/DFS/MS/2010/2600 dated 07-09-2010. The premises was re inspected by the officers concerned of this department on 09-06-2014 in the presence of Mr. Shyam Suri (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “Assembly” Group D with effect from 17/07/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/07/14 at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer,  
Ph: 011 – 23414250.

Copy to:

1. Sh. Shyam Suri,  
City Banquet,  
40 – B, Rama Road, New Delhi – 110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1/15

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/2014/839 dated 03-04-2014.

**INSPECTION REPORT**

1. Name & address of the building: City Banquet (A Unit of Shree Ganesh Enterprises), 40 – B, Rama Road, New Delhi – 110015.
2. Type of Occupancy : Assembly (Basement + Ground Floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2010/2600 Dated 07-09-2010
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2004/1092 dated 24-05-2004
6. Date of inspection : 09-06-2014
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer  
from the building side : Sh. Shyam Suri (Owner)
9. Year of Construction : 2007
10. Applicant's letter No. : Nil Dated Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	Old Case	Old Case	MR
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft	NA	NA	NA

07-09-2010  
 13/09/2000 Dated  
 5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2004/1092 dated 24-05-2004

6. Date of inspection : 09-06-2014

7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)

8. Name and designation of Officer

from the building side : Sh. Shyam Suri (Owner)

9. Year of Construction : 2007

10. Applicant's letter No. : Nil Dated Nil

\$ No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	Old Case	Old Case	MR
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8 nos.	Provided	MR



	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided	MR
8.	MOEFA	Required	Found Provided	MR
9.	Public Address System	Required	Found Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	2	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	2	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	900 lpm & 180 lpm Provided	MR
	➤ Head of the pump	40 m	Provided	MR
		Required	Found Provided	MR
	➤ Power supply		Provided	
	➤ Auto starting of pump	Required	Found Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> </ul>	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA

117

	• Overhead Tank capacity	20,000 litres	Provided	MR
15.	Exit Signage	Required	Found Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2010/2600 Dated 07-09-2010 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name **MUKESH VERMA**

Name

Designation **AO (N.N)**

Designation

**AO (West)** *da*  
*3/7*