

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/FW/2014/MDZ/888

Dated: 18/07/14

FIRE SAFETY CERTIFICATE

Certified that the M/s Dhoom Singh Fireworks at Shop no. D-28/1, Khasra No.152/2, Madhuban Mohalla, Gali No.1, Main Yamuna Vihar Road, North Ghonda, Delhi, owned/occupied by M/s Dhoom Singh Fireworks, building comprised of ground floor only was granted FSC vide letter no.F5/(GA)/DFS/2011/153 dated 24.06.2011. The Fireworks shop have deemed complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officer concerned of this department on dated-02/07/2014 in the presence of Sh.Dhoom Singh and found that the shop is fit for occupancy class Fireworks storage (Manufactured Fireworks 300Kg + Chinese/Sparklers 1200 Kg.) with effect from.....18/07/14.....for a period of three years, subject to conditions printed overleaf.

Issued on .....18/07/14..... at New Delhi by



(Dr. G.C. Misra)  
Chief Fire Officer  
Ph.011-23414333

o/c  
ly

To,

Sh. Dhoom Singh  
M/s Dhoom Singh Fireworks  
Shop no. D-28/1, Khasra No.152/2,  
Madhuban Mohalla, Gali No.1, North Ghonda,  
Main Yamuna Vihar Road, Delhi,

Copy to:-

The Addl. Commissioner of police (Licensing),  
1<sup>st</sup> Floor, P.S. Defence colony,  
New Delhi.

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/directions of the Licensing Department shall always be permitted and followed
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : M/s Dhoom Singh Fireworks at Shop no. D-28/1, Khasra No.152/2, Madhuban Mohalla, Gali No.1, Main Yamuna Vihar Road, North Ghonda, Delhi.
2. Type of Occupancy : Storage Fireworks
3. Type of Case : Renewal
4. Details of Previous FSC : F5/(3A)/DFS/2011/153 Dated 24.06.2014
5. Fire Safety direction letter No : -----
6. Date of Inspection : 02/07/2014
7. Name of the Inspecting Officers : ADO Vijay Bahadur
8. Name of the Person from the Building side : Sh.Dhoom Singh
9. Year of Construction : 2005
10. Applicant letter no. : 11/06/2014

Sr. No.	Point of Inspection	Requirement	Provided at Site	MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m <sup>2</sup> (Min.)	20 m <sup>2</sup>	MR
	b. Construction	Pucca	Provided	MR
	c. Premises Location	Not under the staircase/Mean s of escape	Provided	MR
	d. Business permissible only at ground floor level	Required	Provided	MR
	e. Business from pavement of road prohibited	prohibited	Yes,	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit	Required	Provided (Yes)	MR
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/ inflammable or hazardous materials.	Required	Provided (15 mtrs. away)	MR

4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes.	Required	Provided (yes)	MR
5.	Type of electrical wiring and electrical fittings			
	Preferably concealed or through conduit	Required	Provided	MR
	All electrical fitting should be flame/spark proof	Required	Provided with laid through conduit.	MR
6	Extension of Shop for Business.	Prohibited	Yes	MR
7	Approach Road			
	The road width on the side of which premises is located should be 12m.	12 M	13 M	MR
8	Fire Protection Arrangement.			
	Extinguishers (Type & No's.)	2 nos. water type & 1 no. of ABC or Co2 type	Provided	MR
	Sand and Water Buckets	2 nos. each	Provided	MR
	Water Drum(s)	1 nos.	Provided	MR
9	Any other point that is contrary to the safety of people.		Nil	

The fire protection systems provided in shop were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules. The fire safety certificate issued vide letter no. F.5/(3A)/DFS/2011/153 dated-24.06.2011, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DO/ED

*Vijay Bahadur*  
8/7/14

Signature of the Inspecting Officer  
Name-Vijay Bahadur  
Designation-ADO



Submitted for approval please.

Dy CPO/N1232

*Vijay Bahadur*  
11/7/14

