

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52 / 869

Dated: 16/7/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Garima Public School** located at Near Holi Chowk, Village Ghuman Hera, New Delhi-110073. The building is comprised of ground floor plus two upper floors but the school is running at ground floor plus one upper floor only was issued NOC by this department vide letter No.F.6/MS/DFS/2006/2381 dated 08.09.2006 for ground floor plus one upper floor. The School building was re-inspected by the officer concerned of this department on 30.06.2014 in the presence of Sh. Sunil Kumar (Manager) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (**Ground floor plus one upper floor only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... 16/7/14at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Manager,
Garima Public School, Near Holi Chowk,
Village Ghuman Hera, New Delhi-110073.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

OTC Sano
14/7/14

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N)2
Ground plus two upper floors (but school at Ground plus one upper floor)
 (Renewal).

INSPECTION REPORT

1. Name & address of the building: Gaonia Public School, Near Holi Chowk, Vill Ghuman, Meerut, N Delhi - 110073
2. Type of Occupancy : Educational.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F6/MS/DFS/2006/2381 Dated 08/09/06
5. Fire Safety directives letter No : _____
6. Date of inspection : 30-06-2014
7. Name of Inspecting Officer : AOO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr. Sunil Kumar (Manager)
9. Year of Construction : 2004-2005
10. Applicant's letter No. : G.P.S./June 2014/17 dt 23-06-2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p>	<p>4.5 mtr</p> <p>2.5 mtr</p>	<p>MR</p> <p>MR</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>One</p> <p>—</p>	<p>Two</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>1.5 mtr</p> <p>—</p>	<p>150 < 135 cms</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		—	01	—
	e. Width of Corridor	—	155 cms	—
	f. Door Size	1 mtr	Two 90 cms.	MR (old case, shutters less than 45 in each door)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p> <p>—</p>	<p>—</p> <p>Natural Ventilation</p>	<p>No Basement</p> <p>MR</p>

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	07 No's ABC/CO ₂ ISI marked	Provided do do	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	— 30 m 5 mm	— — —	— — —
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	— — — — —	— — — — —	— — — — —
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	— — —	— — —	— — —
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	— — —	— — —	— — —
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	— —	— —	— —
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	— — — — — — — —	— — — — — — —	— — — — — — —

Gaurima Public School, Near Holi Chalk, Vill Guman Hera, Delhi-110073

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.	—	—	—
16.	Provision of Lifts.			no lift
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/S

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. FG/MS/DFS/2006/2381 dated 08/09/2006 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note :- The building comprised of ground plus two upper floor has school running on ground & one upper floor (as per undertaking given by manager placed on C-4). The upper floor is served by two staircases having width 150 & 135 cms. There are two doors of 90cms width in each class room, there are less than 45 students in each class as per undertaking given by manager placed on C-4 - Sandeep 07/07/2014. FSC is recommended for renewal please.

Signature of Inspecting Officer

Signature of Inspecting Officer

Name Sandeep Duggal

Name

Designation Asst. Divisional Officer

Designation

DO (SW)

Renewal F.S.C. for G+1 upper floor only (in G+2 floor) school is put up for kind approval & signature please.