

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI -110001

E-mail :- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593


FIRE SAFETY CERTIFICATE

NO. F.6/DFS/MS/2014 / 52 / 864

Dated: 14/07/14

Certified that the Banquet Hall in the name and style of M/s Le Grand Signature Banquet at A-146, Mayapuri Industrial Area - II, New Delhi is comprised of basement, ground floor, first floor and second floor. The building was inspected by the officers concerned of Fire Service on 27.06.2014 in presence of Sh. Surender Kumar Setia (owner) and found that the banquet hall owner has complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class D-3 "Banquet Hall building" with effect from 14/07/14...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....14/07/14.....at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph :- 011-23414333

Copy to,

- 1 Sh Surender Kumar Setia,  
A-146, Mayapuri Industrial area, Phase-II,  
New Delhi.
- 2 Executive Engineer (Bldg)-I  
MCD, Building Department,  
8<sup>th</sup> Floor, Civic Centre,  
Minto Road, New Delhi.

Following fire safety directives must be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
2. Any loss of life or property due to non-functional fire safety measures shall be risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Basement, Ground floor plus the upper floors

N/8

(New Case)

**INSPECTION REPORT**

1. Name & address of the building: Le Grand Signature Banquet, A-146, Mayapuri ind Area, Ph II, ND
2. Type of Occupancy: Assembly D-3
3. Type of Case: New Case / Renewal
4. Details of previous NOC: —
5. Fire Safety directives letter No: FC/DFS/MS/BP/2014/423 dated 20/01/2014
6. Date of inspection: 27/06/2014
7. Name of the Inspecting Officers: Do. S.K. Tomar and ADO. Sandeep Duggal
8. Name and designation of officers from the building side: Sh. Surender Kumar Setia
9. Year of Construction: 2009
10. Applicant's letter No.: Nil dated Nil

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	9 mtr	12 mtr	MR
	• Gate width	4.5 mtr	open entry (18mm)	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02 No's	02 No's	MR
	• Basements	02 No's	02 No's	MR
	b. Width of staircases			
	• Upper Floors	1.5 mtr	150 & 150cms	MR
	• Basements	1.5 mtr	150 & 150cms	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	01	—
	g. Width of Corridor	—	opening in hall	—
	h. Door Size	2 mtr	375, 270 & 170cms	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR



N/9

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required	Provided	MR
		—	—	—
		—	—	—
		—	—	—
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	Exhaust fans	MR
		12 a/c per hour	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	20 No <sup>15</sup> ABC/CO <sub>2</sub> /WCO <sub>2</sub> ISI marked	25 No <sup>15</sup> Provided	MR MR
			— do —	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	one 30 m 5 mm	provided — do — — do —	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke type At entrance — Required in hall	provided — do — — — provided — do —	MR MR — MR MR
8	<b>MOEFA</b>	Required	— do —	MR
9	<b>Public Address System.</b>	Required	— do —	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required — —	provided — —	MR — —
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm one one	provided — do — — do —	MR MR MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	— —	— —	— —

Jay





N/11

	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~

Note:- Banquet hall building is comprised of ground floor, basement, first floor & second floor. Basement & upper floors are accessible by two staircases having width 150 cms each. FSC is recommended please.

Signature of the Inspecting Officer


Signature of the Inspecting Officer

Name S. K. Tomar

Name Sandeep Duggal

Designation Divisional officer

Designation Asst. Divisional officer



Sandeep  
02/07/2014