

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2014/w2/875

Dated: 17 / 07 / 2014

FIRE SAFETY CERTIFICATE

Certified that **Holy Father Model School, Pratap Vihar, Gole Market, Kirari Ext. Delhi-110086** comprised of **Ground Floor only** owned / occupied by **Holy Father Model School** has already been issued fire safety certificate **vide letter no. F.6/DFS/MS/2011/1062 Dated 02/06/2011.** The premises was re-inspected by the officer from this department on dated **23/06/2014** in the presence of **Mrs. Poonam (Principal)** and observed that the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of **Circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **17 / 07 / 2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 17/07/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Holy Father Model School, Pratap Vihar, Gole Market, Kirari Ext. Delhi-110086
2. The Director of Education, Old Secretariat, Delhi

N →

Ground floor only.

INSPECTION REPORT

1. Name & address of the building : Holy Father Model School Prataf Vihar Gole
2. Type of Occupancy : Educational
3. Type of Case : New case/ Renewal
4. Details of previous NOC : F.6/DLS/MS/2011/1062
5. Fire Safety directives letter No : Dir. of Edu. Circular - 1-3-2011 dt. 2.6.2011
6. Date of inspection : 23.6.14 dt. 17.1.05
7. Name of the Inspecting Officers : ADO (BWS)
8. Name and designation of officers from the building side : Smt Poojaram Principal.
9. Year of Construction : 2009
10. Applicant's letter No. : Lt No. Nil dt. 8.5.14

Plot area- 900 m² Covered area- 400 m² No's of student- 400 No's of class room-

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MIR
	• Gate width	-do-	-do-	MR
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			
3	Compartmentation.			
	• Fire check door	old case	old case	old case
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			

N/A

N/A

8. Name and designation of officers *Smt Poo nam Principal.*
from the building side :

9. Year of Construction : *2009*

10. Applicant's letter No. : *lt No. Nil dt. 8.5.14*

Plot area- *900 m²* Covered area- *400 m²* No's of student- *400* No's of class room-

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<i>Accessable</i>	<i>Accessable</i>	<i>MR</i>
	• Gate width	<i>-do-</i>	<i>-do-</i>	<i>MR</i>
	• Width of internal road	<i>-</i>	<i>-</i>	<i>-</i>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<i>old case</i>	<i>old case</i>	<i>old case</i>
3	Compartmentation.			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers			
	• Total numbers	<i>3 ABC</i>	<i>4</i>	<i>MR</i>
	• Types	<i>ISI marked</i>	<i>ABC</i>	<i>MR</i>
	• IS marking		<i>yes</i>	<i>MR</i>

14-8

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none">Total numbers on each floor	One at each floor		N/A
	<ul style="list-style-type: none">Length of hose reel hose	30 m		
	<ul style="list-style-type: none">Nozzle diameter	5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none">Type of detectors			N/A
	<ul style="list-style-type: none">Location of Main Panel			
	<ul style="list-style-type: none">Location of Repeater Panel			
	<ul style="list-style-type: none">Alternate source of power			
	<ul style="list-style-type: none">Hooters' Location			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none">Basement			N/A
	<ul style="list-style-type: none">Upper Floor			
	<ul style="list-style-type: none">Sprinkler above false ceiling			
11	Internal Hydrants			
	<ul style="list-style-type: none">Size of riser/down-comer			N/A
	<ul style="list-style-type: none">Number of hydrants per floor			
	<ul style="list-style-type: none">Hose Box			
12	Yard Hydrants.			
	<ul style="list-style-type: none">Total number of hydrants			N/A
	<ul style="list-style-type: none">Hose Box			
13	Pumping Arrangements.			
	<ul style="list-style-type: none">Ground Level			N/A
	<ul style="list-style-type: none">➤ Discharge of main Pump			
	<ul style="list-style-type: none">➤ Head of Main pump			
	<ul style="list-style-type: none">➤ Number of main pumps			
	<ul style="list-style-type: none">➤ Jockey Pump out put			
	<ul style="list-style-type: none">➤ Jockey pump head			
	<ul style="list-style-type: none">➤ Standby Pump out put			
	<ul style="list-style-type: none">➤ Standby Pump Head			
	<ul style="list-style-type: none">➤ Auto Starting/ Manual stopping			
	<ul style="list-style-type: none">➤ Pump House Access			
	<ul style="list-style-type: none">Terrace level			
	<ul style="list-style-type: none">➤ Discharge of pump			
	<ul style="list-style-type: none">➤ Head of the pump			

14-9

	<ul style="list-style-type: none"> ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers...~~ *Previous P.S.C. issued vide Lt-NO. P-6/DFS/MS/2011/1062 dt. 2-6-2011.*

Signature of the Inspecting Officer

Name

Designation

*CFO/726
8/2/14
18/8/14*

Ad (P/S)
3/7/14

Signature of the Inspecting Officer

Name

Designation

Ad (P/S)
26/6/14

ADD (BW)