

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No. F6/DFS/MS/GH/2014/1402/858

Dated: 14/07/14

**FIRE SAFETY CERTIFICATE**

Certified that the: M/S Shivam Guest House, 3,Katra Baryan,Lal Kaun Road, Faehpuri , Delhi-6, comprised of Ground floor (Commercial use others properties), 1<sup>st</sup> floor (4 Rooms+Reception), 2<sup>nd</sup> floor (5 Rooms) and 3<sup>rd</sup> floor (06Rooms+Pantry) was granted NOC by this department vide letter No. F6/DFS/MS/GH/2011/2370, dated 30-09-2011. The premises was re-inspected by the officer concerned of this department on 05-07-2014 in the presence of Mr. Sachin Sharma (Owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of total 15 guest rooms at first floor to third floor only with effect from .14.07.2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .14.07.14. at New Delhi by.



(Dr.G.C.Misra)  
Chief Fire Officer  
T.No.011-23414333

oe  
h

Copy to:-

1. The Joint. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049 w.r.t. letter No.22563/Addl. C.P./Lic.(H), dated 12.06.14.
2. M/S Shivam Guest House, 3,Katra Baryan, Faehpuri , Delhi-6.

**Conditions for the validity of fire safety certificate are overleaf:-**

**INSPECTION REPORT**

1. Name & address of the building : M/S Shivam Guest House, 3, Katra Bariyan,  
Lal Kaun Road, Faehpuri, Delhi-6.
2. Building is comprised of : G+3, ( Guest house is at 1<sup>st</sup> floor to 3<sup>rd</sup> floor, 15 rooms )  
(Ground floor is commercial others properties).
3. Type of Occupancy : Lodging House
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/GH/2011/2370, dated-30.09.11.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 05.07.2014
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer  
from the building side : Sh. Sachin Sharma (Owner)
10. Year of Construction : 1960.
11. Applicant's letter No : No.22563/Joint. C.P./Lic.(H), dated 12.06.14.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks (P.S.S. Area)
1	Access to building			
	Road width	N.A.	9 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size				
	01 no.	01 no.		MR
	N.A.	N.A.		N.A.
	80 cms.	87 to 90cms.		MR
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	1no.	1no.		MR
N.A.	N.A.		N.A.	
N.A.	N.A.		N.A.	
3	Compartmentation			
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
4	Smoke Management System.			
Basement Upper floor	30a/c per hour	N.A.		N.A.
	12 a/c per hour	N.A.		N.A.






5.	Fire Extinguisher			
	Total numbers	06 nos.	06 nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on 1 <sup>st</sup> & 3 <sup>rd</sup> floor	02nos.	02nos.	MR
	Length of hose reel hose	30m.	30m.	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	01no.	01no.	MR
	➤ Head of the Pump	225LPM	225LPM	MR
	➤ Power supply	40m.	40m.	MR
	➤ Auto Starting of pump	Required	Provided	MR
		N.A	N.A.	N.A.

N/17

M/S Shivam Guest House, 3, Katra Baryan, Faehpuri, Delhi-6.


14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	2500Liters.	2500Liters.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/GH/2011/2370, dated 30.09.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO



D.O. (Central)

Vedpal  
8/7/14