

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/dfs/ms/school/2014/w2/874

Dated: 17 / 7 / 2014

FIRE SAFETY CERTIFICATE

Certified that St. Samuel Model School, E-2/14, 15, 17 & 17A, Budh Vihar, Phase-I, Delhi-110086 comprised of Ground Floor owned / occupied by St. Samuel Model School has already been issued fire safety certificate vide letter no. F.6/DFS/MS/2006/1920 Dated 04/08/2006 (Ground floor only). The premises was re-inspected by the officer from this department on dated 19/06/2014 in the presence of Vikas (Manager) and observed that the school now comprise of Ground + one upper floor. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of Circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 17 / 7 / 2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 17 / 07 / 14 at New Delhi by


(SANTOSH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, St. Samuel Model School, E-2/14, 15, 17 & 17A, Budh Vihar, Phase-I, Delhi -110086
2. The Director of Education, Old Secretariat, Delhi



N/6

Renewal Earlier - G.F
Presently - G.F + F.F. Recently - G.F + F.F

Earlier G.F only

Presently - G.F + F.F.

Recently - G.F + F.F

INSPECTION REPORT

1. Name & address of the building : ST. Samuel Model school, E-2/14, 15, 17, 17A
2. Type of Occupancy : Budh Vihar I, Delhi 86, Educational
3. Type of Case : New case/ Renewal
4. Details of previous NOC : F-6/DFS/MS/2006/1920 dt 04-8-2006
5. Fire Safety directives letter No : Circular of the director of Edm
6. Date of inspection : 19-6-14
7. Name of the Inspecting Officers : N.P. Sharma
8. Name and designation of officers from the building side : Sr. Vikash
9. Year of Construction : 2013
10. Applicant's letter No. : SMS/2014/Fire/ dt 30-4-14

Plot area-1400 sqds Covered area-800 sqds No's of student-269 No's of class room- 18

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR ✓
	• Upper Floors	01	02	MR ✓
	• Basements	-	-	-
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.6 mtr each	MR ✓
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	1.08 mtr	MR ✓
3	Compartmentation.	NIA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	Smoke Management System.	NIA		
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-

8. Name and designation of officers : Sh. Vikash
 from the building side :
 9. Year of Construction : 2013
 10. Applicant's letter No. : SMS/2014/Fire/ dt 30-4-14

Plot area-1400 sqds Covered area-800 sqds No's of student-269 No's of class room- 18

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR ✓
	• Upper Floors	01	02	MR ✓
	• Basements	-	-	-
	b. Width of staircases	1.5 mtr	1.6 mtr each	MR ✓
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	1.08 mtr	MR ✓
3	Compartmentation.	NIA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	Smoke Management System.	NIA		
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-
5	Fire Extinguishers			
	• Total numbers	04	06	MR ✓
	• Types		ABC type	MR ✓
	• IS marking	ISI marked	yes	MR ✓
6	First-Aid Hose Reels.	NIA		

15

1/7

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One at each floor 30 m 5 mm			
7	Automatic fire detection and alarming system.				
		NIA			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
		NIA			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 				
11	Internal Hydrants				
		NIA			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 				
12	Yard Hydrants.				
		NIA			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 				
13	Pumping Arrangements.				
		NIA			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 				
14	Captive Water Storage for fire fighting.				
		NIA			
	<ul style="list-style-type: none"> Underground tank capacity 				

9	Public Address System.			
10	Automatic Sprinkler System.	NIA		
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants	NIA		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.	NIA		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.	NIA		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
14	Captive Water Storage for fire fighting.	NIA		
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 			
15	Exit Signage.			

N/S

16	Provision of Lifts.	N/A		
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.	N/A		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	N/A		
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

* Earlier Noc was issued for G.F. only vide F-6/DFs/MS/2006/1920 dt 04-8-06.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name N.P. Sharma

Designation ADD 'R'

DOPW

30/6/14

Signature of the Inspecting Officer

Name

Designation