

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Hospital/2014/885 Dated: 18/07/2014

FIRE SAFETY CERTIFICATE

Certified that the **Sunder Lal Jain Charitable Hospital** located at Ashok Vihar, Phase-III, Delhi-110052, comprised of Ground + three Upper Floors owned/occupied by M/s **Sunder Lal Jain Charitable Hospital**, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **05-06-2014** in the presence of **Prakash Chander & Rajinder Sharma** and that the building/premises is fit for **Class-C (Institutional)** building with effect from 18/07/2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

- 1) Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
- 2) All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
- 3) The fire suppression/protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
- 4) Any lose of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the license.
- 5) This report may not in any way be treated as regularization of unauthorized construction, if any.
- 6) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in
- 7) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on.....18/07/14.....at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
E-mail: cfowz.dfire@nic.in
Tel No. 011- 23414250

Copy to:
Mr Deepak Jain (Director)
Sunder Lal Jain Charitable Hospital
Ashok Vihar, Phase-III, Delhi-110052



21/21

INSPECTION REPORT

1. Name & address of the building : Sunder Lal Jain Charitable Hospital located at Ashok Vihar, Phase-III, Delhi-110052.
2. Type of Occupancy : Institutional (Ground + three Upper Floors)
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : F6/MS/DFS/BP/1992/829 dated 04.05.1992
6. Date of inspection : 05-06-2014
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
 From the building side : Mr. Prakash Chander & Rajinder Sharma
9. Year of Construction : 1992-93
10. Applicant's letter No. : nil dated 29.04.2014

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	16 mtr	Provided ✓	M.R.
	• Gate width	5 mtr	Provided ✓	M.R.
	• Width of internal road	Required	Provided ✓	M.R.
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	2	4 + 1 ramp ✓	M.R.
	• Basement	N.A.	N.A.	N.A.
b.	Width of staircases			
	• Upper Floors	2 x 2 m	Provided ✓	M.R.
	• Basement	N.A.	N.A.	N.A.
c.	Protection of exits			
	• Fire check door	Required	Provided ✓	M.R.
	• Pressurization	N.A.	N.A.	N.A.
d.	No. of continuous staircases to terrace	1	Provided ✓	M.R.
e.	Width of Corridor	1.2 m	1.3 mtr, 1.76mtr, 2.75mtr ✓	M.R.
f.	Door size	2 mtr	Provided ✓	M.R.

6. Date of inspection : 05-06-2014
 7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
 8. Name and designation of officers
 From the building side : Mr. Prakash Chander & Rajinder Sharma
 9. Year of Construction : 1992-93
 10. Applicant's letter No. : nil dated 29.04.2014

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	16 mtr	Provided ✓	M.R.
	• Gate width	5 mtr	Provided ✓	M.R.
	• Width of internal road	Required	Provided ✓	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	4 + 1 ramp ✓	M.R.
	• Basement	N.A.	N.A.	N.A.
	b. Width of staircases			
	• Upper Floors	2 x 2 m	Provided ✓	M.R.
	• Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	• Fire check door	Required	Provided ✓	M.R.
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	1	Provided ✓	M.R.
	e. Width of Corridor	1.2 m	1.3 mtr, 1.76mtr, 2.75mtr ✓	M.R.
	f. Door size	2 mtr	Provided ✓	M.R.
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	N.A. <i>No shaft in the bldg.</i>	N.A.	N.A.

	• Number of hydrants per floor	03	Provided	M.R.
	• Hose Box	Required 03 hose box at each floor	Provided	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	06	Provided	M.R.
	• Hose Box	06	Provided	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	1620 LPM	2280 LPM	M.R.
	➤ Head of Main pump	60 mtrs	70 mtr	M.R.
	➤ Number of main pumps	1	1	M.R.
	➤ Jockey Pump out put	180 LPM	450 LPM	M.R.
	➤ Jockey pump head	60 mtr	70 mtr	M.R.
	➤ Standby pump out put	1620 LPM	2280 LPM	M.R.
	➤ Standby pump Head	60 mtrs	70 mtr	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	N.R.	N.R.	N.R.
	➤ Head of the pump	N.R.	N.R.	N.R.
	➤ Power supply	N.R.	N.R.	N.R.
	➤ Auto Starting of pump	N.R.	N.R.	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	1,00,000 ltrs	Provided	M.R.
	➤ Draw -off connection	N.A.	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.

13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	1620 LPM	2280 LPM	M.R.
	➤ Head of Main pump	60 mtrs	70 mtr	M.R.
	➤ Number of main pumps	1	1	M.R.
	➤ Jockey Pump out put	180 LPM	450 LPM	M.R.
	➤ Jockey pump head	60 mtr	70 mtr	M.R.
	➤ Standby pump out put	1620 LPM	2280 LPM	M.R.
	➤ Standby pump Head	60 mtrs	70 mtr	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	N.R.	N.R.	N.R.
	➤ Head of the pump	N.R.	N.R.	N.R.
	➤ Power supply	N.R.	N.R.	N.R.
	➤ Auto Starting of pump	N.R.	N.R.	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	1,00,000 ltrs	Provided	M.R.
	➤ Draw -off connection	N.A.	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.
	➤ Overhead Tank Capacity	10,000 ltrs	20,000 ltrs provided	M.R.
15	Exit Signage.	Required	Provided	M.R.

N/24

16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	Required	Provided	M.R.
	• Fireman's Grounding Switch	Required	Provided	M.R.
	• Lift Signage	Required	Provided	M.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19.	Fire Control Room			
	➤ Detector System Panel	N.A.	N.A.	N.A.
	➤ Flow Switch Panel	N.A.	N.A.	N.A.
	➤ PA system Panel	N.A.	N.A.	N.A.
	➤ Battery backup	N.A.	N.A.	N.A.
	➤ Building Floor plans	N.A.	N.A.	N.A.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Signature of the Inspection Officer

Name Sunil Chawdhary

Designation D.O.(M.N.)

Signature of the Inspection Officer

Name

Designation

CA/209
2/2/14
9/9/13