

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/GH/2014/402/892

Dated: 18/07/14

FIRE SAFETY CERTIFICATE

Certified that the Vaishnav Hotel, 23-25, 640, Fatehpuri, Delhi-6, comprises of ground plus four upper floors one block and ground plus three upper floors in another block owned / occupied by Sh. Dilip Kumar & Sh. Vinod Kumar, was granted NOC by this department vide letter No. F6/DFS/MS/GH/2011/401 dated 28-02-11. The premises was re-inspected by the officer concerned of this department on 14-07-2014 in the presence of Sh. Dilip Kumar (owner) and found that the said hotel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential (Guest House) (Ground floor- 06 guest rooms, 03 stores, clock & luggage room & reception, 1st floor -12 guest rooms, 2rd & 3rd floor-20 guest rooms & 01 store at each floor, 4th floor-15 guest rooms & 6 staff rooms, water tank DG Set, Fiber sheet shed & pentry) total 73 guest rooms in all with effect from ...18/07/2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued ..18/07/14 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
T.No.011-23414333

Copy to:-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony ,
New Delhi-110049 w.r.t. letter No 11880/Addl. C.P./Lic.(H) dated 10.03.14.
2. Vaishnav Hotel, 23-25, 640, Fatehpuri, Delhi-6.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Vaishnav Hotel, 23-25, 640, Fatehpuri, Delhi-6
2. Building is comprised of : One Block G+4 & One block G+3, (Total 73 rooms).
3. Type of Occupancy : Lodging House
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/GH/2011/401 Dated-28.2.2011
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 14.07.2014
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of officer
from the building side : Sh. Dilip Sharma (Manager)
10. Year of Construction : 1925
11. Applicant's letter No. : No.11880/Addl.C.P./Lic.(H) dated 10.03.14.

S.N	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks (P.S.S. Area)
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases Upper Floor	3 nos.	3 nos. (1 block having 1 no. & 1 block having 1 No. from ground to Terrace & 1 from 2 nd Floor to terrace)	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases Upper Floor	100, 105 cms (80 cms from 2 nd Floor to terrace)	100 & 105 cms. (80 cms from 2 nd Floor to terrace) in 25, Fatehpuri	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace.	1 no.	1 no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
	3	Compartmentation		
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30 a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

5.	Fire Extinguisher			
	Total numbers	24 nos.	30 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor in one Block only	01no.	01	MR
	Length of hose reel hose	30 m	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450LPM	MR
	➤ Head of the Pump	40 Mtrs.	40Mtrs.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

Vaishnav Hotel, 23-25, 640, Fatehpuri, Delhi-6

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	50000 Ltrs.	50000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Required	Provided	MR
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	D.G. Set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/GH/2011/401 dated 28.2.11 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO

